Quad Cities 1

3Q/2008 Performance Indicators

Licensee's General Comments: none



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2209.0	2159.0	1755.3	2139.0	2209.0	2183.0	2184.0	2208.0
Indicator value	**0.9**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2209.0	2159.0	1755.3	2139.0	2209.0	2183.0	2184.0	2208.0
Indicator value	**2.6**	**1.7**	**0.8**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value				**0.0**	**0.0**	**0.0**	**0.0**	**0.0**

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
Safety System Functional Failures	0	0	0	0	0	2	0	1
Indicator value	**3**	**0**	**0**	**0**	**0**	**2**	**2**	**3**

Licensee Comments:

3Q/08: LER 1-08-001 Past Operation of Safe Shutdown Makeup Pump Outside Technical Specifications Surveillance Requirements dated 9/8/08. (Note SSMP failure counts against both unit.)

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
UAI (ΔCDF)	1.10E-08	2.30E-09	-5.70E-08	-3.30E-08	-7.00E-08	4.70E-08	9.90E-11	4.70E-09
URI (ΔCDF)	-4.70E-07	-5.20E-07	-5.40E-07	-5.30E-07	-5.10E-07	-1.10E-07	-9.60E-08	-9.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-4.59E-07**	**-5.18E-07**	**-5.97E-07**	**-5.63E-07**	**-5.80E-07**	**-6.30E-08**	**-9.59E-08**	**-9.23E-08**

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
UAI (ΔCDF)	3.00E-08	3.50E-08	6.40E-09	4.40E-08	4.00E-08	2.40E-08	2.40E-08	2.40E-08
URI (ΔCDF)	-4.30E-08	-4.30E-08	-4.30E-08	-4.30E-08	-4.20E-08	-3.60E-08	-3.40E-08	-3.40E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-1.30E-08**	**-8.00E-09**	**-3.66E-08**	**1.00E-09**	**-2.00E-09**	**-1.20E-08**	**-1.00E-08**	**-1.00E-08**

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
UAI (ΔCDF)	-6.10E-09	-3.30E-09	-2.30E-08	-2.10E-08	-2.10E-08	-1.70E-08	-1.70E-08	-1.70E-08
URI (ΔCDF)	-3.20E-08	-3.20E-08	-3.40E-08	-3.40E-08	-3.40E-08	9.50E-08	9.90E-08	9.90E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-3.81E-08**	**-3.53E-08**	**-5.70E-08**	**-5.50E-08**	**-5.50E-08**	**7.80E-08**	**8.20E-08**	**8.20E-08**

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
UAI (ΔCDF)	-7.70E-08	-2.80E-08	-3.90E-08	-5.00E-08	-7.10E-08	-5.60E-08	-2.70E-08	-2.70E-08
URI (ΔCDF)	-1.30E-07	-1.20E-07	-1.20E-07	-1.20E-07	-1.20E-07	-9.70E-08	-9.70E-08	-9.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-2.07E-07**	**-1.48E-07**	**-1.59E-07**	**-1.70E-07**	**-1.91E-07**	**-1.53E-07**	**-1.24E-07**	**-1.24E-07**

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
UAI (ΔCDF)	7.70E-08	1.50E-07	1.50E-07	1.60E-07	1.10E-07	-9.40E-09	3.20E-08	3.20E-08
URI (ΔCDF)	4.20E-09	4.20E-09	4.20E-09	4.20E-09	4.20E-09	2.80E-09	1.90E-09	1.90E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**8.12E-08**	**1.54E-07**	**1.54E-07**	**1.64E-07**	**1.14E-07**	**-6.60E-09**	**3.39E-08**	**3.39E-08**

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	**10/06**	**11/06**	**12/06**	**1/07**	**2/07**	**3/07**	**4/07**	**5/07**	**6/07**	**7/07**	**8/07**	**9/07**
Maximum activity	0.000115	0.000119	0.000128	0.000113	0.000126	0.000085	0.000106	0.000053	0.000081	0.000054	0.000063	0.000046
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	**0.1**	**0.1**	**0.1**	**0.1**	**0.1**	**0**	**0.1**	**0**	**0**	**0**	**0**	**0**
Reactor Coolant System Activity	**10/07**	**11/07**	**12/07**	**1/08**	**2/08**	**3/08**	**4/08**	**5/08**	**6/08**	**7/08**	**8/08**	**9/08**
Maximum activity	0.000052	0.000099	0.000063	0.000055	0.000062	0.000393	0.000031	0.000041	0.000042	0.000052	0.000072	0.000053
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	**0**	**0**	**0**	**0**	**0**	**0.2**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	10/06	11/06	12/06	1/07	2/07	3/07	4/07	5/07	6/07	7/07	8/07	9/07
Maximum leakage	1.760	1.700	1.720	1.690	1.670	1.670	1.650	1.720	1.710	1.690	1.910	1.920
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	**7.0**	**6.8**	**6.9**	**6.8**	**6.7**	**6.7**	**6.6**	**6.9**	**6.8**	**6.8**	**7.6**	**7.7**
Reactor Coolant System Leakage	**10/07**	**11/07**	**12/07**	**1/08**	**2/08**	**3/08**	**4/08**	**5/08**	**6/08**	**7/08**	**8/08**	**9/08**
Maximum leakage	1.600	1.590	1.560	1.560	1.560	1.540	1.550	1.550	1.550	1.620	1.620	1.570
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	**6.4**	**6.4**	**6.2**	**6.2**	**6.2**	**6.2**	**6.2**	**6.2**	**6.2**	**6.5**	**6.5**	**6.3**

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
Successful opportunities	88.0	26.0	23.0	42.0	41.0	30.0	32.0	24.0
Total opportunities	89.0	26.0	23.0	42.0	42.0	30.0	32.0	24.0
Indicator value	**98.0%**	**98.6%**	**98.6%**	**98.5%**	**98.5%**	**99.1%**	**99.4%**	**99.4%**

Licensee Comments: none



Notes

ERO Drill Participation	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
Participating Key personnel	81.0	75.0	74.0	72.0	70.0	69.0	70.0	69.0
Total Key personnel	81.0	75.0	74.0	72.0	70.0	70.0	73.0	69.0
Indicator value	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**98.6%**	**95.9%**	**100.0%**

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
Successful siren-tests	3270	3311	3316	3320	3312	3312	3284	3367
Total sirens-tests	3272	3328	3328	3328	3328	3319	3309	3380
Indicator value	**99.7%**	**99.6%**	**99.6%**	**99.7%**	**99.6%**	**99.7%**	**99.6%**	**99.5%**

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08	2Q/08	3Q/08
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Security information not publicly available.

Last Modified: November 26, 2008