Limerick 2

2Q/2011 Performance Indicators

Licensee's General Comments: none



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
Unplanned scrams	0	0	0	0	0	0	1.0	1.0
Critical hours	2208.0	2209.0	2159.0	2184.0	2208.0	2209.0	2024.4	1592.4
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0.8**	**1.7**

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
Unplanned power changes	1.0	0	0	0	0	2.0	1.0	0
Critical hours	2208.0	2209.0	2159.0	2184.0	2208.0	2209.0	2024.4	1592.4
Indicator value	**3.4**	**2.5**	**0.8**	**0.8**	**0**	**1.6**	**2.4**	**2.6**

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
UAI (ΔCDF)	1.40E-08	3.50E-09	4.67E-09	9.27E-09	8.01E-09	8.00E-09	7.78E-09	7.98E-09
URI (ΔCDF)	-2.30E-07	-6.00E-08	6.47E-09	2.54E-08	6.02E-09	6.92E-09	-1.14E-08	6.50E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-2.16E-07**	**-5.65E-08**	**1.10E-08**	**3.50E-08**	**1.40E-08**	**1.50E-08**	**-3.60E-09**	**1.40E-08**

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	**3Q/09**	**4Q/09**	**1Q/10**	**2Q/10**	**3Q/10**	**4Q/10**	**1Q/11**	**2Q/11**
UAI (ΔCDF)	1.80E-08	-1.20E-08	-1.22E-08	-2.50E-08	-3.20E-08	-3.20E-08	-3.20E-08	-3.20E-08
URI (ΔCDF)	7.40E-07	4.00E-07	3.98E-07	-4.60E-08	-4.61E-08	-4.62E-08	-4.62E-08	-4.63E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**7.58E-07**	**3.88E-07**	**3.90E-07**	**-7.10E-08**	**-7.80E-08**	**-7.80E-08**	**-7.80E-08**	**-7.80E-08**

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	**3Q/09**	**4Q/09**	**1Q/10**	**2Q/10**	**3Q/10**	**4Q/10**	**1Q/11**	**2Q/11**
UAI (ΔCDF)	-9.80E-09	7.00E-09	5.00E-09	-1.06E-08	2.65E-09	2.30E-09	2.63E-09	-6.05E-10
URI (ΔCDF)	2.00E-07	1.10E-07	1.13E-07	-2.71E-08	-2.71E-08	-2.71E-08	-2.71E-08	-2.71E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**1.90E-07**	**1.17E-07**	**1.20E-07**	**-3.80E-08**	**-2.40E-08**	**-2.50E-08**	**-2.40E-08**	**-2.80E-08**

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
UAI (ΔCDF)	3.40E-08	4.40E-08	4.23E-08	3.74E-08	4.07E-08	3.87E-08	3.83E-08	3.06E-08
URI (ΔCDF)	4.50E-08	-1.30E-09	-1.17E-09	-1.18E-09	-1.31E-09	-1.36E-09	-1.38E-09	-2.16E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**7.90E-08**	**4.27E-08**	**4.10E-08**	**3.60E-08**	**3.90E-08**	**3.70E-08**	**3.70E-08**	**2.80E-08**

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
UAI (ΔCDF)	1.00E-07	1.40E-07	1.52E-07	1.96E-07	2.70E-07	3.71E-07	3.40E-07	3.19E-07
URI (ΔCDF)	-4.10E-09	-2.50E-08	-2.56E-08	-2.66E-08	-2.79E-08	-2.85E-08	-2.81E-08	-2.85E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**9.59E-08**	**1.15E-07**	**1.30E-07**	**1.70E-07**	**2.40E-07**	**3.40E-07**	**3.10E-07**	**2.90E-07**

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	**7/09**	**8/09**	**9/09**	**10/09**	**11/09**	**12/09**	**1/10**	**2/10**	**3/10**	**4/10**	**5/10**	**6/10**
Maximum activity	0.000011	0.000011	0.000010	0.000010	0.000012	0.000010	0.000011	0.000011	0.000009	0.000011	0.000011	0.000014
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**
Reactor Coolant System Activity	**7/10**	**8/10**	**9/10**	**10/10**	**11/10**	**12/10**	**1/11**	**2/11**	**3/11**	**4/11**	**5/11**	**6/11**
Maximum activity	0.000013	0.000013	0.000025	0.000013	0.000014	0.000012	0.000014	0.000013	0.000015	0.000013	0.000010	0.000006
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	**7/09**	**8/09**	**9/09**	**10/09**	**11/09**	**12/09**	**1/10**	**2/10**	**3/10**	**4/10**	**5/10**	**6/10**
Maximum leakage	1.300	1.400	1.400	1.400	1.500	1.400	1.400	1.500	1.500	1.400	1.450	1.350
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	**5.2**	**5.6**	**5.6**	**5.6**	**6.0**	**5.6**	**4.7**	**5.0**	**5.0**	**4.7**	**4.8**	**4.5**
Reactor Coolant System Leakage	**7/10**	**8/10**	**9/10**	**10/10**	**11/10**	**12/10**	**1/11**	**2/11**	**3/11**	**4/11**	**5/11**	**6/11**
Maximum leakage	1.400	1.300	1.400	1.500	1.500	1.400	1.500	1.400	1.400	1.200	1.300	1.400
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	**4.7**	**4.3**	**4.7**	**5.0**	**5.0**	**4.7**	**5.0**	**4.7**	**4.7**	**4.0**	**4.3**	**4.7**

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
Successful opportunities	57.0	17.0	12.0	23.0	59.0	43.0	66.0	20.0
Total opportunities	59.0	17.0	12.0	24.0	61.0	43.0	68.0	20.0
Indicator value	**97.1%**	**97.2%**	**97.0%**	**98.5%**	**97.7%**	**97.6%**	**97.4%**	**97.7%**

Licensee Comments: none



Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
Participating Key personnel	65.0	68.0	69.0	65.0	64.0	65.0	65.0	64.0
Total Key personnel	65.0	68.0	69.0	65.0	66.0	65.0	65.0	64.0
Indicator value	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**97.0%**	**100.0%**	**100.0%**	**100.0%**

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
Successful siren-tests	2141	2145	2142	2140	2144	2143	2144	2144
Total sirens-tests	2145	2145	2145	2145	2145	2145	2145	2145
Indicator value	**99.8%**	**99.8%**	**99.9%**	**99.9%**	**99.9%**	**99.9%**	**99.9%**	**99.9%**

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
High radiation area occurrences	0	0	0	0	0	0	0	1
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**1**

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Security information not publicly available.

Last Modified: July 22, 2011