


Point Beach 2

3Q/2013 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Unplanned scrams	0	0	1.0	0	0	0	0	0
Critical hours	2209.0	2183.0	2108.8	2162.0	1516.5	2159.0	2184.0	2208.0
Indicator value	1.1	1.0	0.8	0.8	0.9	0.9	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Unplanned power changes	0	0	0	0	0	0	0	1.0
Critical hours	2209.0	2183.0	2108.8	2162.0	1516.5	2159.0	2184.0	2208.0
Indicator value	0	0.9						

Licensee Comments:

3Q/13: Power reduction due to steam leak on main feedwater pump 2P-28A. Power was reduced and the main feedwater pump steam leak was repaired.

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0							

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Safety System Functional Failures	0	0	0	1	0	0	0	0
Indicator value	3	1	0	1	1	1	1	0


Licensee Comments:

3Q/12: LER 266/2012-003 is for both units but was a SSFF only for Unit 2. Submitted August 28, 2012.

1Q/12: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

4Q/11: There were no LERs submitted in 4Q11.

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	1.04E-07	6.79E-08	8.00E-08	9.30E-08	8.67E-08	5.28E-08	5.89E-08	5.54E-08
URI (Δ CDF)	-2.90E-07	-2.89E-07	-2.88E-07	-2.86E-07	-2.85E-07	-2.84E-07	-7.46E-07	-7.41E-07
PLE	NO							
Indicator value	-1.90E-07	-2.20E-07	-2.10E-07	-1.90E-07	-2.00E-07	-2.30E-07	-6.90E-07	-6.90E-07

Licensee Comments:

3Q/13: Revised estimated run hours to account for endurance tests. (RWT01837653) Effective 4Q13. ESF starts added from Feb 2013 (AR01890255).

2Q/13: MSPI Basis Document has been updated to incorporate PRA Model 5.01 which was implemented March 1, 2013. This version of the PRA model incorporates a new data analysis using plant data from 2003-2008.

2Q/13: Changed PRA Parameter(s). MSPI Basis Document has been updated to incorporate PRA Model 5.01 which was implemented March 1, 2013. This version of the PRA model incorporates a new data analysis using plant data from 2003-2008.

1Q/13: MSPI Basis Document Rev 20 issued, no PRA parameters changed.

1Q/13: MSPI Basis Document Rev 20 issued, no PRA parameters changed.


1Q/12: Oct 11 and Nov 11UA revised for cascaded unavailability. (AR01754772) PRA parameters were updated to

reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

4Q/11: MSPI Basis Document updated for account for change in first hour of run time per FAQ 480.

4Q/11: MSPI Basis Document updated for account for change in first hour of run time per FAQ 480. PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (ΔCDF)	1.39E-08	1.80E-08	2.13E-08	2.21E-08	2.56E-08	1.01E-08	-2.94E-09	-6.12E-09
URI (ΔCDF)	3.98E-07	3.90E-07	3.90E-07	3.90E-07	3.90E-07	3.90E-07	2.20E-07	2.20E-07
PLE	NO	NO						
Indicator value	4.10E-07	4.10E-07	4.10E-07	4.10E-07	4.20E-07	4.00E-07	2.20E-07	2.10E-07

Licensee Comments:

2Q/13: Changed PRA Parameter(s). Failure 247779 for 2P-15B oiler being empty had erroneously been changed to not a failure. This has been corrected (AR01883159). MSPI Basis Document has been updated to incorporate PRA Model 5.01 which was implemented March 1, 2013. This version of the PRA model incorporates a new data analysis using plant data from 2003-2008.

1Q/13: MSPI Basis Document Rev 20 issued, no PRA parameters changed.

1Q/13: MSPI Basis Document Rev 20 issued, no PRA parameters changed.


1Q/12: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

1Q/12: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

4Q/11: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

4Q/11: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat								
--	--	--	--	--	--	--	--	--

Removal System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	1.09E-08	2.53E-09	2.33E-09	2.98E-09	4.48E-09	5.35E-09	-9.87E-09	-9.18E-09
URI (Δ CDF)	-9.77E-09	-9.98E-09	-1.01E-08	-1.02E-08	-1.03E-08	-1.03E-08	-4.42E-08	-4.37E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.10E-09	-7.50E-09	-7.80E-09	-7.20E-09	-5.80E-09	-5.00E-09	-5.40E-08	-5.30E-08

Licensee Comments:

3Q/13: Revised estimated operational demands and run hours for P-053 motor driven pump. Pump not used for startup and shutdown operation. (RWT01837653 and AR01903536) Effective 4Q13.


2Q/13: Changed PRA Parameter(s). MSPI Basis Document has been updated to incorporate PRA Model 5.01 which was implemented March 1, 2013. This version of the PRA model incorporates a new data analysis using plant data from 2003-2008.

1Q/13: MSPI Basis Document Rev 20 issued, no PRA parameters changed.

1Q/12: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

4Q/11: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (ΔCDF)	3.73E-08	3.50E-08	3.67E-08	3.87E-08	4.04E-08	4.08E-08	1.06E-07	9.83E-08
URI (ΔCDF)	-2.24E-08	-2.24E-08	-2.24E-08	-2.24E-08	-2.24E-08	-2.24E-08	-1.23E-07	-1.23E-07
PLE	NO							
Indicator value	1.50E-08	1.30E-08	1.40E-08	1.60E-08	1.80E-08	1.80E-08	-1.60E-08	-2.50E-08

Licensee Comments:

3Q/13: Revised estimated demands for valves due to venting. (RWT01837653) Effective 4Q13.


2Q/13: Changed PRA Parameter(s). MSPI Basis Document has been updated to incorporate PRA Model 5.01 which was implemented March 1, 2013. This version of the PRA model incorporates a new data analysis using plant data from 2003-2008.

1Q/13: MSPI Basis Document Rev 20 issued, no PRA parameters changed.

1Q/12: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

4Q/11: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	5.45E-08	4.19E-09	-1.94E-08	-2.29E-08	-1.38E-08	-1.40E-08	-1.64E-08	-1.64E-08
URI (Δ CDF)	-2.80E-08	1.59E-08	1.59E-08	-2.90E-08	-2.90E-08	-2.90E-08	-7.79E-09	-7.79E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.70E-08	2.00E-08	-3.50E-09	-5.20E-08	-4.30E-08	-4.30E-08	-2.40E-08	-2.40E-08

Licensee Comments:

3Q/13: Revised estimated demands and run hours for current normal operation. (RWT01837653) Effective 4Q13.


2Q/13: Changed PRA Parameter(s). MSPI Basis Document has been updated to incorporate PRA Model 5.01 which was implemented March 1, 2013. This version of the PRA model incorporates a new data analysis using plant data from 2003-2008.

1Q/13: MSPI Basis Document Rev 20 issued, no PRA parameters changed.

1Q/12: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

4Q/11: PRA parameters were updated to reflect PRA Model Rev 4.04 which incorporated Unit 2 extended power uprate modifications. Model 4.04 was implemented on Dec 20, 2011 and is being used for 1Q12 reporting.

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum activity	0.000189	0.000188	0.000204	0.000213	0.000214	0.000228	0.000223	0.000247	0.000244	0.000287	0.000261	0.000284
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0	0	0	0	0	0	0	0	0	0.1	0.1	0.1
Reactor Coolant System Activity	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum activity	0.000278	N/A	0.000139	0.000165	0.000156	0.000155	0.000164	0.000172	0.000185	0.000194	0.000196	0.000207
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.1	N/A	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum leakage	0.020	0.180	0.070	0.215	0.160	0.220	0.149	0.160	0.216	0.159	0.334	0.359
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	1.8	0.7	2.2	1.6	2.2	1.5	1.6	2.2	1.6	3.3	3.6
Reactor Coolant System Leakage	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum leakage	0.662	0.200	0.025	0.027	0.031	0.039	0.049	0.049	0.054	0.045	0.060	0.048
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	6.6	2.0	0.3	0.3	0.3	0.4	0.5	0.5	0.5	0.5	0.6	0.5


Licensee Comments:

12/12: 2012-10 Maximum RCS Identified Leakage revised 5/22/13 to 0.662 based on data review from AR 1872894. 2012-11 Maximum RCS Identified Leakage revised 5/22/13 to 0.200 based on data review from AR 1872894.

12/11: 2011-12 Maximum RCS Identified Leakage revised 5/22/13 to 0.070 based on data review from AR

1872894.

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Successful opportunities	2.0	54.0	40.0	27.0	2.0	38.0	31.0	27.0
Total opportunities	2.0	55.0	44.0	27.0	2.0	38.0	32.0	28.0
Indicator value	98.1%	97.8%	96.0%	95.9%	96.2%	96.7%	97.0%	96.9%

Licensee Comments:

2Q/12: Successful opportunities revised from 29 to 28 for April based on the actual Alert declaration being retracted on 8/2/12.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Participating Key personnel	59.0	63.0	63.0	61.0	59.0	64.0	62.0	63.0
Total Key personnel	60.0	63.0	63.0	61.0	59.0	64.0	62.0	63.0
Indicator value	98.3%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Successful siren-tests	98	97	96	98	98	97	98	84
Total sirens-tests	98	98	98	98	98	98	98	84
Indicator value	99.5%	99.5%	99.2%	99.2%	99.2%	99.2%	99.7%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0							

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0							

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 22, 2013