Quad Cities 1

1Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2067.9	2208.0	2209.0	2159.0	2184.0	2208.0	2209.0	1668.0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned power changes	0	0	0	0	0	0	0	1.0
Critical hours	2067.9	2208.0	2209.0	2159.0	2184.0	2208.0	2209.0	1668.0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0.8**

Licensee Comments: none



Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**

Licensee Comments: none



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Safety System Functional Failures	0	0	0	0	0	0	0	1
Indicator value	**1**	**1**	**0**	**0**	**0**	**0**	**0**	**1**

Licensee Comments:

1Q/15: LER 254/2014-005-00, Main Control Room Door Unable to Close Causes Loss of Control Room Envelope Boundary (affects BOTH units)

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	**2Q/13**	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**
UAI (ΔCDF)	-2.12E-10	9.23E-09	2.38E-08	1.46E-08	1.07E-08	8.61E-09	9.43E-09	2.75E-08
URI (ΔCDF)	-7.19E-08	-7.15E-08	-7.16E-08	-6.72E-08	-6.51E-08	-6.43E-08	-6.50E-08	-6.52E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-7.20E-08**	**-6.20E-08**	**-4.80E-08**	**-5.30E-08**	**-5.40E-08**	**-5.60E-08**	**-5.60E-08**	**-3.80E-08**

Licensee Comments:

4Q/14: Includes endurance run and short work window

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	**2Q/13**	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**
UAI (ΔCDF)	2.30E-08	2.03E-08	1.92E-08	1.41E-08	1.33E-08	1.30E-08	1.32E-08	1.57E-08
URI (ΔCDF)	-1.49E-08	-1.49E-08	-1.49E-08	-1.43E-08	-1.37E-08	-1.37E-08	-1.37E-08	-1.49E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**8.10E-09**	**5.40E-09**	**4.30E-09**	**-2.40E-10**	**-4.00E-10**	**-7.30E-10**	**-4.70E-10**	**7.80E-10**

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	**2Q/13**	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**
UAI (ΔCDF)	6.91E-10	1.16E-09	1.11E-09	4.77E-10	-1.20E-09	-9.18E-10	4.42E-10	-2.35E-09
URI (ΔCDF)	-1.26E-08	-1.31E-08	-1.31E-08	-1.31E-08	-1.15E-08	-1.15E-08	-1.15E-08	-1.31E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-1.20E-08**	**-1.20E-08**	**-1.20E-08**	**-1.30E-08**	**-1.30E-08**	**-1.20E-08**	**-1.10E-08**	**-1.50E-08**

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	**2Q/13**	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**
UAI (ΔCDF)	-2.38E-08	-2.38E-08	-2.38E-08	-2.38E-08	-2.38E-08	-2.38E-08	-2.38E-08	-2.38E-08
URI (ΔCDF)	-4.06E-08	-4.06E-08	-4.06E-08	-4.06E-08	-4.06E-08	-4.06E-08	-4.06E-08	-4.06E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-6.40E-08**	**-6.40E-08**	**-6.40E-08**	**-6.40E-08**	**-6.40E-08**	**-6.40E-08**	**-6.40E-08**	**-6.40E-08**

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	**2Q/13**	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**
UAI (ΔCDF)	5.89E-08	5.86E-08	6.52E-08	3.23E-08	3.68E-08	3.68E-08	3.68E-08	3.80E-08
URI (ΔCDF)	-5.28E-10	-5.28E-10	-5.28E-10	-5.28E-10	-5.28E-10	-5.28E-10	-5.28E-10	-5.28E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**5.80E-08**	**5.80E-08**	**6.50E-08**	**3.20E-08**	**3.60E-08**	**3.60E-08**	**3.60E-08**	**3.70E-08**

Licensee Comments: none



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	**4/13**	**5/13**	**6/13**	**7/13**	**8/13**	**9/13**	**10/13**	**11/13**	**12/13**	**1/14**	**2/14**	**3/14**
Maximum activity	0.000013	0.000014	0.000010	0.000012	0.000015	0.000009	0.000014	0.000014	0.000014	0.000017	0.000015	0.000014
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**
Reactor Coolant System Activity	**4/14**	**5/14**	**6/14**	**7/14**	**8/14**	**9/14**	**10/14**	**11/14**	**12/14**	**1/15**	**2/15**	**3/15**
Maximum activity	0.000021	0.000021	0.000024	0.000028	0.000039	0.000030	0.000037	0.000035	0.000035	0.000029	0.000041	0.000027
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	**4/13**	**5/13**	**6/13**	**7/13**	**8/13**	**9/13**	**10/13**	**11/13**	**12/13**	**1/14**	**2/14**	**3/14**
Maximum leakage	1.580	1.760	1.640	1.572	1.563	1.656	1.628	1.676	1.629	1.592	1.558	1.526
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	**6.3**	**7.0**	**6.6**	**6.3**	**6.3**	**6.6**	**6.5**	**6.7**	**6.5**	**6.4**	**6.2**	**6.1**
Reactor Coolant System Leakage	**4/14**	**5/14**	**6/14**	**7/14**	**8/14**	**9/14**	**10/14**	**11/14**	**12/14**	**1/15**	**2/15**	**3/15**
Maximum leakage	1.514	1.488	1.462	1.433	1.448	1.438	1.438	1.472	1.429	1.426	1.426	1.533
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	**6.1**	**6.0**	**5.8**	**5.7**	**5.8**	**5.8**	**5.8**	**5.9**	**5.7**	**5.7**	**5.7**	**6.1**

Licensee Comments: none



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful opportunities	47.0	31.0	26.0	15.0	51.0	40.0	22.0	28.0
Total opportunities	47.0	33.0	26.0	15.0	52.0	45.0	22.0	28.0
Indicator value	**98.6%**	**97.8%**	**97.6%**	**97.3%**	**97.7%**	**96.3%**	**96.9%**	**97.0%**

Licensee Comments: none



Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Participating Key personnel	70.0	71.0	73.0	73.0	73.0	72.0	75.0	76.0
Total Key personnel	70.0	71.0	73.0	73.0	73.0	72.0	75.0	76.0
Indicator value	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**

Licensee Comments: none



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful siren-tests	2684	2686	2687	2641	2687	2686	2686	2641
Total sirens-tests	2688	2688	2688	2646	2688	2688	2688	2646
Indicator value	**99.9%**	**99.9%**	**99.9%**	**99.9%**	**99.9%**	**99.9%**	**99.9%**	**99.9%**

Licensee Comments: none



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

Action Matrix Summary | Inspection Findings Summary | PI Summary | Reactor Oversight Process

Last Modified: April 23, 2015