Oconee 2

2Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2208.0	923.5	2159.0	2184.0	2208.0	2166.9	2159.0	2184.0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2208.0	923.5	2159.0	2184.0	2208.0	2166.9	2159.0	2184.0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**	**0.0**

Licensee Comments: none



Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	**1**	**1**	**1**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
UAI (ΔCDF)	2.86E-08	3.84E-08	7.80E-08	8.83E-08	1.29E-07	1.21E-07	1.78E-07	1.90E-07
URI (ΔCDF)	7.39E-08	1.02E-07	1.02E-07	1.02E-07	5.72E-08	5.72E-08	2.95E-07	3.24E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**1.00E-07**	**1.40E-07**	**1.80E-07**	**1.90E-07**	**1.90E-07**	**1.80E-07**	**4.70E-07**	**5.10E-07**

Licensee Comments:

4Q/14: Five breakers were added as MSPI-monitored components for the Emergency AC Power System to resolve discrepancies between the MSPI Basis Document and the CDE configuration. This change did not result in a threshold change.

3Q/14: Changed PRA Parameter(s).

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s).

4Q/13: Changed PRA Parameter(s).

3Q/13: Changed PRA Parameter(s).

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**	**2Q/15**
UAI (ΔCDF)	-7.25E-10	-7.59E-10	-7.59E-10	-7.59E-10	-7.59E-10	-7.59E-10	-7.67E-10	-7.67E-10
URI (ΔCDF)	-1.34E-07	-1.34E-07	-1.34E-07	-1.34E-07	-1.34E-07	-1.34E-07	-1.51E-07	-1.51E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-1.40E-07**	**-1.40E-07**	**-1.40E-07**	**-1.40E-07**	**-1.40E-07**	**-1.40E-07**	**-1.50E-07**	**-1.50E-07**

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**	**2Q/15**
UAI (ΔCDF)	4.02E-08	6.02E-08	3.37E-09	1.27E-08	2.36E-09	1.07E-09	-4.40E-08	-4.81E-08
URI (ΔCDF)	-7.95E-08	-7.95E-08	-7.95E-08	-7.95E-08	-7.95E-08	-7.95E-08	-8.07E-08	-8.07E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-3.90E-08**	**-1.90E-08**	**-7.60E-08**	**-6.70E-08**	**-7.70E-08**	**-7.80E-08**	**-1.20E-07**	**-1.30E-07**

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**	**2Q/15**
UAI (ΔCDF)	4.63E-08	2.20E-07	2.14E-07	2.61E-07	7.72E-07	7.29E-07	4.11E-07	4.12E-07
URI (ΔCDF)	-9.65E-08	-9.65E-08	-9.65E-08	-9.65E-08	-9.65E-08	-9.65E-08	-1.12E-07	-1.12E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-5.00E-08**	**1.20E-07**	**1.20E-07**	**1.60E-07**	**6.80E-07**	**6.30E-07**	**3.00E-07**	**3.00E-07**

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	**3Q/13**	**4Q/13**	**1Q/14**	**2Q/14**	**3Q/14**	**4Q/14**	**1Q/15**	**2Q/15**
UAI (ΔCDF)	-7.31E-08	-8.82E-08	-8.43E-08	-8.48E-08	-6.55E-08	-6.81E-08	-6.11E-08	-4.52E-08
URI (ΔCDF)	-3.00E-08	-3.00E-08	-3.00E-08	-3.00E-08	-3.00E-08	-3.00E-08	-3.00E-08	-3.00E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	**-1.00E-07**	**-1.20E-07**	**-1.10E-07**	**-1.10E-07**	**-9.50E-08**	**-9.80E-08**	**-9.10E-08**	**-7.50E-08**

Licensee Comments: none



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	**7/13**	**8/13**	**9/13**	**10/13**	**11/13**	**12/13**	**1/14**	**2/14**	**3/14**	**4/14**	**5/14**	**6/14**
Maximum activity	0.000588	0.000374	0.000994	0.000422	N/A	0.000144	0.000147	0.000192	0.000226	0.000169	0.000241	0.000281
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	**0.1**	**0**	**0.1**	**0**	**N/A**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Reactor Coolant System Activity	**7/14**	**8/14**	**9/14**	**10/14**	**11/14**	**12/14**	**1/15**	**2/15**	**3/15**	**4/15**	**5/15**	**6/15**
Maximum activity	0.000189	0.000154	0.000182	0.000325	0.000182	0.000244	0.000189	0.000748	0.000700	0.000199	0.000197	0.000263
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0.1**	**0.1**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	**7/13**	**8/13**	**9/13**	**10/13**	**11/13**	**12/13**	**1/14**	**2/14**	**3/14**	**4/14**	**5/14**	**6/14**
Maximum leakage	0.118	0.072	0.059	0.142	N/A	0.086	0.095	0.078	0.093	0.083	0.073	0.083
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	**1.2**	**0.7**	**0.6**	**1.4**	**N/A**	**0.9**	**1.0**	**0.8**	**0.9**	**0.8**	**0.7**	**0.8**
Reactor Coolant System Leakage	**7/14**	**8/14**	**9/14**	**10/14**	**11/14**	**12/14**	**1/15**	**2/15**	**3/15**	**4/15**	**5/15**	**6/15**
Maximum leakage	0.144	0.158	0.141	0.150	0.155	0.168	0.181	0.178	0.199	0.179	0.072	0.065
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	**1.4**	**1.6**	**1.4**	**1.5**	**1.6**	**1.7**	**1.8**	**1.8**	**2.0**	**1.8**	**0.7**	**0.7**

Licensee Comments: none



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
Successful opportunities	33.0	36.0	64.0	10.0	60.0	11.0	32.0	28.0
Total opportunities	34.0	36.0	66.0	10.0	61.0	12.0	34.0	28.0
Indicator value	**96.6%**	**96.8%**	**97.0%**	**97.0%**	**96.9%**	**96.4%**	**97.0%**	**97.5%**

Licensee Comments: none



Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
Participating Key personnel	133.0	148.0	150.0	151.0	146.0	143.0	148.0	132.0
Total Key personnel	133.0	148.0	150.0	151.0	146.0	143.0	148.0	132.0
Indicator value	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**	**100.0%**

Licensee Comments: none



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
Successful siren-tests	1816	1748	1681	1686	1818	1749	1678	1754
Total sirens-tests	1820	1755	1690	1690	1820	1755	1690	1755
Indicator value	**99.7%**	**99.7%**	**99.6%**	**99.7%**	**99.7%**	**99.7%**	**99.7%**	**99.7%**

Licensee Comments: none



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	**0**	**0**	**0**	**0**	**0**	**0**	**0**	**0**

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

Action Matrix Summary | Inspection Findings Summary | PI Summary | Reactor Oversight Process

Last Modified: July 24, 2015