


Ginna

3Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2209.0	2159.0	1617.0	2208.0	2209.0	2159.0	2184.0	2208.0
Indicator value	0.8	0.8	0.9	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Unplanned power changes	0	2.0	1.0	1.0	0	0	0	0
Critical hours	2209.0	2159.0	1617.0	2208.0	2209.0	2159.0	2184.0	2208.0
Indicator value	0	1.6	2.6	3.4	3.4	1.7	0.8	0

Licensee Comments:

1Q/14: After further review of the data it has been determined that the unplanned downpower in January 2014 is more correctly counted as two separate Initiating Events instead of one, as previously reported. The performance indicator remains in the 'Green' performance band.

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0							

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Safety System Functional Failures	1	0	0	0	1	0	0	0
Indicator value	1							

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	-1.19E-07	-1.39E-07	-1.39E-07	-1.25E-07	4.16E-08	4.95E-09	1.38E-09	-9.91E-10
URI (Δ CDF)	-5.36E-07	-5.28E-07	-5.00E-07	3.69E-10	1.93E-08	4.92E-09	6.07E-09	6.07E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.50E-07	-6.70E-07	-6.40E-07	-1.20E-07	6.10E-08	9.90E-09	7.50E-09	5.10E-09

Licensee Comments:

2Q/15: Unavailable hours previously reported for EDG A for the month of June 2015 were classified as Unplanned, and are now being reported as planned because no failure of the EDG had occurred. This improves the resulting MSPI value, and does not change the MSPI indicator color (green) for June 2015.

4Q/14: Risk Cap Invoked.


3Q/14: Risk Cap Invoked.

2Q/14: The reservoir cup of an oil mister for the A EDG air start motor was found disconnected in March. The event is not classified as an MSPI failure. Engineering analysis has confirmed the operability assessment of the EDG while the oiler cup was disconnected.

1Q/14: The reservoir cup of an oil mister for the A EDG air start motor was found disconnected in March. The event is not classified as an MSPI failure. A confirmatory analysis will supplement the Apparent Cause Evaluation

to document the basis for this conclusion.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	1.13E-09	1.08E-09	6.01E-10	6.01E-10	-1.75E-09	7.46E-10	-2.42E-09	-2.42E-09
URI (Δ CDF)	-4.46E-09	-4.46E-09	-4.46E-09	-4.46E-09	-4.46E-09	-4.07E-09	-4.07E-09	-4.07E-09
PLE	NO							
Indicator value	-3.30E-09	-3.40E-09	-3.90E-09	-3.90E-09	-6.20E-09	-3.30E-09	-6.50E-09	-6.50E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	1.80E-08	1.79E-08	3.50E-08	2.55E-08	3.27E-08	8.98E-09	1.33E-08	1.33E-08
URI (Δ CDF)	3.95E-07	4.18E-07	4.27E-07	4.27E-07	5.03E-07	1.93E-07	1.93E-07	1.93E-07
PLE	NO							
Indicator value	4.10E-07	4.40E-07	4.60E-07	4.50E-07	5.40E-07	2.00E-07	2.10E-07	2.10E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (ΔCDF)	3.72E-09	-8.64E-09	-8.64E-09	-8.64E-09	-8.64E-09	7.07E-09	8.05E-09	6.12E-10
URI (ΔCDF)	-2.15E-08	-2.15E-08	-2.15E-08	-2.15E-08	-2.15E-08	-1.77E-08	-1.77E-08	-1.77E-08
PLE	NO							
Indicator value	-1.80E-08	-3.00E-08	-3.00E-08	-3.00E-08	-3.00E-08	-1.10E-08	-9.60E-09	-1.70E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	4.26E-08	4.71E-08	4.45E-08	4.72E-08	4.99E-08	7.25E-08	3.44E-08	3.44E-08
URI (Δ CDF)	2.06E-07	2.06E-07	4.61E-08	4.61E-08	4.61E-08	1.04E-08	1.04E-08	1.04E-08
PLE	NO							
Indicator value	2.50E-07	2.50E-07	9.10E-08	9.30E-08	9.60E-08	8.30E-08	4.50E-08	4.50E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Activity	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum activity	0.002090	0.002150	0.002290	0.002470	0.002820	0.002170	0.002240	N/A	0.001500	0.001260	0.001390	0.001430
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.2	0.2	0.2	0.3	0.2	0.2	N/A	0.2	0.1	0.1	0.1

Reactor Coolant System Activity	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15
Maximum activity	0.001510	0.001680	0.001690	0.001790	0.001890	0.001910	0.001990	0.002140	0.002170	0.002400	0.002130	0.001980
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Licensee Comments:

6/15: Upon review of the previously submitted October 2014 Barrier Integrity Performance Indicator data an error was found for Iodine 131. The value submitted was obtained during a reactor down power which is expected to be excluded from the indicator. There was no change in indicator color resulting from the error.

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum leakage	0.004	0.003	0.004	0.004	0.005	0.008	0.011	0.039	0.027	0.073	0.071	0.071
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0	0	0	0	0.1	0.1	0.1	0.4	0.3	0.7	0.7	0.7

Reactor Coolant System Leakage	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15
Maximum leakage	0.093	0.090	0.101	0.037	0.022	0.022	0.044	0.007	0.007	0.010	0.009	0.015
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.9	0.9	1.0	0.4	0.2	0.2	0.4	0.1	0.1	0.1	0.1	0.2

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Successful opportunities	71.0	92.0	40.0	52.0	82.0	23.0	50.0	38.0
Total opportunities	75.0	94.0	41.0	53.0	84.0	25.0	51.0	39.0
Indicator value	96.0%	96.4%	96.5%	96.5%	96.5%	96.5%	96.7%	97.0%

Licensee Comments:

3Q/14: Late submittal of a drill performance evaluation resulted in an incorrect low count of successful drill opportunities in September 2014. This change reflects the correct value and the indicator remains green.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Participating Key personnel	66.0	47.0	49.0	49.0	50.0	50.0	47.0	45.0
Total Key personnel	66.0	47.0	49.0	50.0	50.0	50.0	47.0	45.0
Indicator value	100.0%	100.0%	100.0%	98.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Successful siren-tests	1248	1241	1343	1243	1245	1247	1245	1245
Total sirens-tests	1248	1248	1344	1246	1248	1248	1248	1248
Indicator value	99.9%	99.8%	99.8%	99.8%	99.7%	99.8%	99.8%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0							

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0							

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: December 15, 2015