

## Farley 2 1Q/2016 Plant Inspection Findings

---

### Initiating Events

---

### Mitigating Systems

**Significance:** G Dec 31, 2015

Identified By: Self-Revealing

Item Type: NCV Non-Cited Violation

#### **Failure to Provide Adequate Instructions for the 2A Service Water Pump Motor Cable Connections**

A self-revealing, non-cited violation of Technical Specification 5.4 "Procedures," was identified for the failure to provide an adequate procedure for installing the 2A service water (SW) pump motor cable connections. As a result, the connection degraded over time, which degraded the Raychem insulation that caused the circuit breaker to trip on overcurrent. The licensee repaired the 2A SW pump motor cable connection under WO SNC717176 and returned the pump to service on October 16, 2015. This event was captured in the licensee's corrective action program with CR 10135057.

The performance deficiency was more than minor because it was associated with the procedure quality attribute of the mitigating systems cornerstone and adversely affected the cornerstone objective because the inadequate procedure resulted in the pump circuit breaker trip due to an overcurrent condition. The significance of this finding was determined to be of very low safety significance (Green). This finding was associated with the cross-cutting aspect of Evaluation in the Problem Identification and Resolution area. [P.2]

Inspection Report# : [2015004](#) (*pdf*)

---

### Barrier Integrity

---

### Emergency Preparedness

---

### Occupational Radiation Safety

---

### Public Radiation Safety

## Security

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page. Therefore, the [cover letters](#) to security inspection reports may be viewed.

---

## Miscellaneous

Last modified : July 11, 2016