



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

REGION IV  
1600 E LAMAR BLVD  
ARLINGTON, TX 76011-4511

September 12, 2016

Clay Warren, Acting Site Vice President  
Arkansas Nuclear One  
Entergy Operations, Inc.  
1448 SR 333  
Russellville, AR 72802-0967

SUBJECT: ERRATA FOR MID-CYCLE ASSESSMENT LETTER FOR ARKANSAS  
NUCLEAR ONE, UNITS 1 AND 2 (REPORT 05000313/2016005 AND  
05000368/2016005)

Dear Mr. Warren:

It was identified that the enclosed inspection plan in a letter to you dated August 31, 2016 (ML16237A412) was improperly marked. The inspection plan contained the markings of "Official Use Only – Sensitive Internal Information/Security-Related Information", however, the inspection plan did not contain information under that category. The inspection plan that was originally placed into ADAMS has been corrected by striking through the markings. The original Mid-Cycle Assessment Letter and the corrected inspection plan are enclosed. Please note that neither the content of the assessment letter, nor the inspection plan has changed.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, its enclosure, and your response (if any) will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's Agency wide Document Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

*/RA/*

Thomas R. Hipschman, Team Leader  
Inspection Program and Assessment Team  
Division of Reactor Safety

Docket Nos.: 50-313, 50-368

License Nos.: DPR-51, NPF-6

Enclosures:

1. Arkansas Nuclear One Units 1 and 2  
Inspection/Activity Plan
2. 2016 Mid-Cycle Assessment  
Letter (ML16237A412)

Page 1 of 3

08/30/2016 09:31:17

Report 22

**Arkansas Nuclear One  
Inspection / Activity Plan  
07/01/2016 - 06/30/2018**

Unit Number	Planned Dates		Inspection Activity	Title	No. of Staff on Site
	Start	End			
<b>EXAM - INITIAL EXAM ANO U1</b>					<b>6</b>
1	07/25/2016	07/29/2016	X02568	INITIAL EXAM ANO UNIT 1 (08/2016)	
1	08/22/2016	09/02/2016	X02568	INITIAL EXAM ANO UNIT 1 (08/2016)	
<b>RS 5678 - RADIATION SAFETY - TEAM</b>					<b>4</b>
1,2	06/27/2016	07/01/2016	IP 71124.05	Radiation Monitoring Instrumentation	
1,2	06/27/2016	07/01/2016	IP 71124.06	Radioactive Gaseous and Liquid Effluent Treatment	
1,2	06/27/2016	07/01/2016	IP 71124.07	Radiological Environmental Monitoring Program	
1,2	06/27/2016	07/01/2016	IP 71124.08	Radioactive Solid Waste Processing and Radioactive Material Handling, Storage, and Transportation	
<b>TSB 52B - BIENNIAL PI&amp;R INSPECTION</b>					<b>5</b>
1,2	08/29/2016	09/02/2016	IP 71152B	Problem Identification and Resolution	
1,2	08/29/2016	09/02/2016	IP 92702	Followup On Corrective Actions For Violations And Deviations	
1,2	09/12/2016	09/16/2016	IP 71152B	Problem Identification and Resolution	
<b>INSP - BIENNIAL REQUAL INSPECTION U1</b>					<b>2</b>
1	07/11/2016	07/15/2016	IP 7111111B	Licensed Operator Requalification Program	
<b>INSP - BIENNIAL REQUAL INSPECTION U2</b>					<b>2</b>
2	07/11/2016	07/15/2016	IP 7111111B	Licensed Operator Requalification Program	
<b>EP-2 - EP PERFORMANCE INDICATORS</b>					<b>2</b>
1	08/15/2016	08/19/2016	IP 71151-EP01	Drill/Exercise Performance	
1	08/15/2016	08/19/2016	IP 71151-EP02	ERO Readiness	
1	08/15/2016	08/19/2016	IP 71151-EP03	Alert & Notification System Reliability	
<b>EP-3 - BIENNIAL EP EXERCISE INSPECTION</b>					<b>4</b>
1,2	08/15/2016	08/19/2016	IP 7111401	Exercise Evaluation	
1,2	08/15/2016	08/19/2016	IP 7111404	Emergency Action Level and Emergency Plan Changes	
<b>EXAM - INITIAL EXAM U2</b>					<b>6</b>
2	01/09/2017	01/13/2017	X02585	INITIAL EXAM ANO UNIT 2 (02/2017)	
2	02/13/2017	02/17/2017	X02585	INITIAL EXAM ANO UNIT 2 (02/2017)	
<b>71111.08 - INSERVICE INSPECTION 1R26</b>					<b>1</b>
1	09/26/2016	10/07/2016	IP 7111108P	Inservice Inspection Activities - PWR	
<b>RS 12 PI - RADIATION SAFETY</b>					<b>2</b>
1,2	10/03/2016	10/07/2016	IP 71124.01	Radiological Hazard Assessment and Exposure Controls	
1,2	10/03/2016	10/07/2016	IP 71124.02	Occupational ALARA Planning and Controls	
1,2	10/03/2016	10/07/2016	IP 71151-OR01	Occupational Exposure Control Effectiveness	
1,2	10/03/2016	10/07/2016	IP 71151-PR01	RETS/ODCM Radiological Effluent Occurrences	

This report does not include INPO and OUTAGE activities.  
This report shows only on-site and announced inspection procedures.

Page 2 of 3

08/30/2016 09:31:17

Report 22

**Arkansas Nuclear One  
Inspection / Activity Plan  
07/01/2016 - 06/30/2018**

Unit Number	Planned Dates		Inspection Activity	Title	No. of Staff on Site
	Start	End			
			<b>EB1-21T - ANO COMPONENT DESIGN BASIS INSPECTION</b>		<b>7</b>
1, 2	10/31/2016	12/02/2016	IP 7111121	Component Design Bases Inspection	
			<b>ISFSI - LOADING INSPECTION (ONE WEEK IN MONTH)</b>		<b>1</b>
1, 2	12/01/2016	12/30/2016	IP 60855.1	Operation of an Independent Spent Fuel Storage Installation at Operating Plants	
			<b>CAL QTR1 - CAL CLOSURE INSPECTION QTR1</b>		<b>4</b>
1, 2	01/01/2017	03/31/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>RS 13 PI - RADIATION SAFETY</b>		<b>3</b>
1, 2	03/13/2017	03/17/2017	IP 71124.01	Radiological Hazard Assessment and Exposure Controls	
1, 2	03/13/2017	03/17/2017	IP 71124.03	In-Plant Airborne Radioactivity Control and Mitigation	
1, 2	03/13/2017	03/17/2017	IP 71151-OR01	Occupational Exposure Control Effectiveness	
1, 2	03/13/2017	03/17/2017	IP 71151-PR01	RETS/ODCM Radiological Effluent Occurrences	
			<b>71111.08 - INSERVICE INSPECTION 2R25</b>		<b>1</b>
2	03/13/2017	03/23/2017	IP 7111108P	Inservice Inspection Activities - PWR	
			<b>EB2-03 - LICENSE RENEWAL INSPECTION (PHASE 1)</b>		<b>2</b>
2	03/20/2017	03/24/2017	IP 71003	Post-Approval Site Inspection for License Renewal	
			<b>CAL QTR2 - CAL CLOSURE INSPECTION QTR2</b>		<b>4</b>
1, 2	04/01/2017	06/30/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>TSB 52B - BIENNIAL PI&amp;R</b>		<b>4</b>
1, 2	05/01/2017	05/05/2017	IP 71152	Problem Identification and Resolution	
1, 2	05/15/2017	05/19/2017	IP 71152	Problem Identification and Resolution	
			<b>CAL QTR3 - CAL CLOSURE INSPECTION QTR3</b>		<b>4</b>
1, 2	07/01/2017	09/30/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>EP-1 - BIENNIAL EP PROGRAM INSPECTION</b>		<b>1</b>
1, 2	07/10/2017	07/14/2017	IP 7111402	Alert and Notification System Testing	
1, 2	07/10/2017	07/14/2017	IP 7111403	Emergency Preparedness Organization Staffing and Augmentation System	
1, 2	07/10/2017	07/14/2017	IP 7111404	Emergency Action Level and Emergency Plan Changes	
1, 2	07/10/2017	07/14/2017	IP 7111405	Correction of Emergency Preparedness Weaknesses and Deficiencies	
			<b>EP-2 - EP PERFORMANCE INDICATOR VERIFICATION</b>		<b>1</b>
1, 2	07/10/2017	07/14/2017	IP 71151-EP01	Drill/Exercise Performance	
1, 2	07/10/2017	07/14/2017	IP 71151-EP02	ERO Readiness	
1, 2	07/10/2017	07/14/2017	IP 71151-EP03	Alert & Notification System Reliability	
			<b>EXAM - INITIAL EXAM</b>		<b>5</b>
1	01/22/2018	01/26/2018	X02628	INITIAL EXAM ANO UNIT 1-(05/18)	

This report does not include INPO and OUTAGE activities.  
This report shows only on-site and announced inspection procedures.

Enclosure 1

Page 3 of 3

08/30/2016 09:31:17

Report 22

**Arkansas Nuclear One**  
**Inspection / Activity Plan**  
**07/01/2016 - 06/30/2018**

Unit Number	Planned Dates		Inspection Activity	Title	No. of Staff on Site
	Start	End			
			<b>EXAM - INITIAL EXAM</b>		<b>5</b>
1	02/26/2018	03/02/2018	X02628	INITIAL EXAM ANO UNIT 1-(05/18)	
			<b>CAL QTR4 - CAL CLOSURE INSPECTION QTR4</b>		<b>4</b>
1,2	10/01/2017	12/31/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>EB1-07T - ANO HEAT SINK PERFORMANCE</b>		<b>1</b>
1,2	10/30/2017	11/03/2017	IP 7111107T	Heat Sink Performance	
			<b>RS 24 - RADIATION SAFETY</b>		<b>3</b>
1,2	11/06/2017	11/10/2017	IP 71124.02	Occupational ALARA Planning and Controls	
1,2	11/06/2017	11/10/2017	IP 71124.04	Occupational Dose Assessment	
			<b>CAL QTR1 - CAL CLOSURE INSPECTION QTR1</b>		<b>4</b>
1,2	01/01/2018	03/31/2018	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>EB2-03 - POST-APPROVAL LICENSE RENEWAL (TEAM)</b>		<b>4</b>
2	01/22/2018	01/26/2018	IP 71003	Post-Approval Site Inspection for License Renewal	
2	02/05/2018	02/09/2018	IP 71003	Post-Approval Site Inspection for License Renewal	
			<b>CAL QTR2 - CAL CLOSURE INSPECTION QTR2</b>		<b>4</b>
1,2	04/01/2018	06/30/2018	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>7111108 - INSERVICE INSPECTION 1R27</b>		<b>1</b>
1	04/09/2018	04/20/2018	IP 7111108P	Inservice Inspection Activities - PWR	

This report does not include INPO and OUTAGE activities.  
This report shows only on-site and announced inspection procedures.

Enclosure 1



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

REGION IV  
1600 E LAMAR BLVD  
ARLINGTON, TX 76011-4511

August 31, 2016

Clay Warren, Acting Site Vice President  
Arkansas Nuclear One  
Entergy Operations, Inc.  
1448 SR 333  
Russellville, AR 72802-0967

**SUBJECT: MID-CYCLE ASSESSMENT LETTER FOR ARKANSAS NUCLEAR ONE,  
UNITS 1 AND 2 (REPORT 05000313/2016005 AND 05000368/2016005)**

Dear Mr. Warren:

On August 11, 2016, the U.S. Nuclear Regulatory Commission (NRC) completed its mid-cycle performance review of Arkansas Nuclear One (ANO), Units 1 and 2. The NRC reviewed the most recent quarterly performance indicators (PIs) in addition to inspection results and enforcement actions from July 1, 2015, through June 30, 2016. This letter informs you of the NRC's assessment of your facility during this period and its plans for future inspections at your facility.

The NRC determined the performance at ANO, Units 1 and 2 during the most recent quarter remained within the Multiple/Repetitive Degraded Cornerstone Column of the NRC's Reactor Oversight Process (ROP) Action Matrix. On March 4, 2015, ANO Units 1 and 2 transitioned to the Multiple/Repetitive Degraded Cornerstone Column (Column 4) of the ROP Action Matrix as a result of having one Yellow finding in each unit involving the failure to adequately approve the design and to load test a temporary lift assembly, and one Yellow finding in each unit involving the failure to design, construct, and maintain plant design features required to protect safety-related equipment from the effects of flooding.

On June 9, 2016, the NRC completed a supplemental inspection and independent review of the causes for declining safety performance at ANO, as well as corrective actions taken and planned to sustain improvement efforts. The NRC inspection team determined that ANO, Units 1 and 2 are being operated safely and Entergy Operations, Inc. (EOI) understands the depth and breadth of performance concerns associated with ANO's performance decline. The NRC team concluded that effective implementation of the licensee's Comprehensive Recovery Plan (CRP), supported by the allocation of adequate resources and continued enhanced oversight by EOI leadership, should lead to substantial and sustained performance improvement. The NRC team identified missed opportunities for ANO to have promptly initiated performance improvements since being placed in Column 4. The NRC team also concluded that your evaluations and corrective actions for three unplanned, Unit 2 scrams that contributed to a White Unplanned Scrams per 7000 Critical Hours PI, were satisfactory. Based on the

**Enclosure 2**

results of this inspection, the White PI was closed. The results of the inspection were documented in NRC Inspection Report 05000313/2016007 and 05000368/2016007 (ML16161B279).

In a letter dated May 17, 2016, "ANO Comprehensive Recovery Plan" (ML16139A059), EOI notified the NRC staff of its plan to perform specific actions to resolve the causes for declining performance at ANO. On June 17, 2016, the NRC issued a Confirmatory Action Letter (ML16169A193) which confirmed EOI commitments to take specific actions included in the "ANO Comprehensive Recovery Plan." The Confirmatory Action Letter groups these actions in six categories:

- Significant performance deficiencies (i.e., actions to address the two Yellow findings)
- Identification, assessment and correction of performance deficiencies
- Human performance
- Equipment reliability and engineering programs
- Safety culture
- Service water self-assessment

The NRC plans to conduct quarterly inspections to review your progress toward completing the ANO Comprehensive Recovery Plan actions that are identified in the Confirmatory Action Letter. The NRC will use Inspection Procedure 92702, "Follow-up on Traditional Enforcement Actions Including Violations, Deviations, Confirmatory Action Letters, Confirmatory Orders, and Alternative Dispute Resolution Confirmatory Orders," to assess your effectiveness in completing corrective actions. The results of these inspections will provide information for future performance assessments of ANO in accordance with NRC Inspection Manual Chapter 0305, "Operating Reactor Assessment Program."

The enclosed inspection plan lists the inspections scheduled through June 30, 2018. Routine inspections performed by resident inspectors are not included in the inspection plan. The inspections listed during the second half of the inspection plan are tentative and may be revised at the end-of-cycle performance review. The NRC provides the inspection plan to allow for the resolution of any scheduling conflicts and personnel availability issues. The NRC will contact you as soon as possible to discuss changes to the inspection plan should circumstances warrant any changes. This inspection plan does not include security related inspections, which will be sent via separate, non-publicly available correspondence.

In response to the accident at Fukushima, the Commission issued Order EA-12-049, "Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events," and Order EA-12-051, "Order Modifying Licenses with Regard to Reliable Spent Fuel Pool Instrumentation." The NRC conducted audits of licensee efforts towards compliance with these Orders, and the information gathered will aid staff in development of the ultimate Safety Evaluation for the site. After the NRC staff receives the Final Compliance letter for the site, the Safety Evaluation will be issued. Then, the NRC staff will confirm through inspections the full implementation of the orders mentioned above by performing Temporary Instruction 191, "Inspection of the Implementation of Mitigation Strategies and Spent Fuel Pool Instrumentation Orders and Emergency Preparedness Communication/Staffing/Multi-Unit Dose Assessment Plans."

In Staff Requirements Memorandum – SECY 16-0009, “Recommendations Resulting from the Integrated Prioritization and Re-Baselining of Agency Activities,” the Commission approved the NRC staff recommendation to discontinue the formal mid-cycle assessment process beginning in calendar year 2017. This will be the final mid-cycle assessment letter. The staff will continue to conduct quarterly assessment meetings and communicate changes in the assessment of licensee performance in accordance with the guidance in Inspection Manual Chapter 0305, “Operating Reactor Assessment Program.”

In accordance with Title 10 of the *Code of Federal Regulations* (10 CFR) 2.390 of the NRC’s “Rules of Practice,” a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC’s Agencywide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Please contact Mr. Neil O’Keefe at 817-200-1574 with any questions you have regarding this letter.

Sincerely,

*/RA/*

Kriss M. Kennedy  
Regional Administrator

Docket Nos. 50-313, 50-368  
License Nos. DPR-51, NPF-6

Enclosure:  
Arkansas Nuclear One Units 1 and 2  
Inspection/Activity Plan

Page 1 of 3

08/30/2016 09:31:17

Report 22

**Arkansas Nuclear One  
Inspection / Activity Plan  
07/01/2016 - 06/30/2018**

Unit Number	Planned Dates		Inspection Activity	Title	No. of Staff on Site
	Start	End			
			<b>EXAM - INITIAL EXAM ANO U1</b>		<b>6</b>
1	07/25/2016	07/29/2016	X02568	INITIAL EXAM ANO UNIT 1 (08/2016)	
1	08/22/2016	09/02/2016	X02568	INITIAL EXAM ANO UNIT 1 (08/2016)	
			<b>RS 5678 - RADIATION SAFETY - TEAM</b>		<b>4</b>
1,2	06/27/2016	07/01/2016	IP 71124.05	Radiation Monitoring Instrumentation	
1,2	06/27/2016	07/01/2016	IP 71124.06	Radioactive Gaseous and Liquid Effluent Treatment	
1,2	06/27/2016	07/01/2016	IP 71124.07	Radiological Environmental Monitoring Program	
1,2	06/27/2016	07/01/2016	IP 71124.08	Radioactive Solid Waste Processing and Radioactive Material Handling, Storage, and Transportation	
			<b>TSB 52B - BIENNIAL PI&amp;R INSPECTION</b>		<b>5</b>
1,2	08/29/2016	09/02/2016	IP 71152B	Problem Identification and Resolution	
1,2	08/29/2016	09/02/2016	IP 92702	Followup On Corrective Actions For Violations And Deviations	
1,2	09/12/2016	09/16/2016	IP 71152B	Problem Identification and Resolution	
			<b>INSP - BIENNIAL REQUAL INSPECTION U1</b>		<b>2</b>
1	07/11/2016	07/15/2016	IP 7111111B	Licensed Operator Requalification Program	
			<b>INSP - BIENNIAL REQUAL INSPECTION U2</b>		<b>2</b>
2	07/11/2016	07/15/2016	IP 7111111B	Licensed Operator Requalification Program	
			<b>EP-2 - EP PERFORMANCE INDICATORS</b>		<b>2</b>
1	08/15/2016	08/19/2016	IP 71151-EP01	Drill/Exercise Performance	
1	08/15/2016	08/19/2016	IP 71151-EP02	ERO Readiness	
1	08/15/2016	08/19/2016	IP 71151-EP03	Alert & Notification System Reliability	
			<b>EP-3 - BIENNIAL EP EXERCISE INSPECTION</b>		<b>4</b>
1,2	08/15/2016	08/19/2016	IP 7111401	Exercise Evaluation	
1,2	08/15/2016	08/19/2016	IP 7111404	Emergency Action Level and Emergency Plan Changes	
			<b>EXAM - INITIAL EXAM U2</b>		<b>6</b>
2	01/09/2017	01/13/2017	X02585	INITIAL EXAM ANO UNIT 2 (02/2017)	
2	02/13/2017	02/17/2017	X02585	INITIAL EXAM ANO UNIT 2 (02/2017)	
			<b>71111.08 - INSERVICE INSPECTION 1R26</b>		<b>1</b>
1	09/26/2016	10/07/2016	IP 7111108P	Inservice Inspection Activities - PWR	
			<b>RS 12 PI - RADIATION SAFETY</b>		<b>2</b>
1,2	10/03/2016	10/07/2016	IP 71124.01	Radiological Hazard Assessment and Exposure Controls	
1,2	10/03/2016	10/07/2016	IP 71124.02	Occupational ALARA Planning and Controls	
1,2	10/03/2016	10/07/2016	IP 71151-OR01	Occupational Exposure Control Effectiveness	
1,2	10/03/2016	10/07/2016	IP 71151-PR01	RETS/ODCM Radiological Effluent Occurrences	

This report does not include INPO and OUTAGE activities.  
This report shows only on-site and announced inspection procedures.

Enclosure

Page 2 of 3

08/30/2016 09:31:17

Report 22

**Arkansas Nuclear One  
Inspection / Activity Plan  
07/01/2016 - 06/30/2018**

Unit Number	Planned Dates		Inspection Activity	Title	No. of Staff on Site
	Start	End			
			<b>EB1-21T - ANO COMPONENT DESIGN BASIS INSPECTION</b>		<b>7</b>
1, 2	10/31/2016	12/02/2016	IP 7111121	Component Design Bases Inspection	
			<b>ISFSI - LOADING INSPECTION (ONE WEEK IN MONTH)</b>		<b>1</b>
1, 2	12/01/2016	12/30/2016	IP 60855.1	Operation of an Independent Spent Fuel Storage Installation at Operating Plants	
			<b>CAL QTR1 - CAL CLOSURE INSPECTION QTR1</b>		<b>4</b>
1, 2	01/01/2017	03/31/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>RS 13 PI - RADIATION SAFETY</b>		<b>3</b>
1, 2	03/13/2017	03/17/2017	IP 71124.01	Radiological Hazard Assessment and Exposure Controls	
1, 2	03/13/2017	03/17/2017	IP 71124.03	In-Plant Airborne Radioactivity Control and Mitigation	
1, 2	03/13/2017	03/17/2017	IP 71151-OR01	Occupational Exposure Control Effectiveness	
1, 2	03/13/2017	03/17/2017	IP 71151-PR01	RETS/ODCM Radiological Effluent Occurrences	
			<b>71111.08 - INSERVICE INSPECTION 2R25</b>		<b>1</b>
2	03/13/2017	03/23/2017	IP 7111108P	Inservice Inspection Activities - PWR	
			<b>EB2-03 - LICENSE RENEWAL INSPECTION (PHASE 1)</b>		<b>2</b>
2	03/20/2017	03/24/2017	IP 71003	Post-Approval Site Inspection for License Renewal	
			<b>CAL QTR2 - CAL CLOSURE INSPECTION QTR2</b>		<b>4</b>
1, 2	04/01/2017	06/30/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>TSB 52B - BIENNIAL PI&amp;R</b>		<b>4</b>
1, 2	05/01/2017	05/05/2017	IP 71152	Problem Identification and Resolution	
1, 2	05/15/2017	05/19/2017	IP 71152	Problem Identification and Resolution	
			<b>CAL QTR3 - CAL CLOSURE INSPECTION QTR3</b>		<b>4</b>
1, 2	07/01/2017	09/30/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>EP-1 - BIENNIAL EP PROGRAM INSPECTION</b>		<b>1</b>
1, 2	07/10/2017	07/14/2017	IP 7111402	Alert and Notification System Testing	
1, 2	07/10/2017	07/14/2017	IP 7111403	Emergency Preparedness Organization Staffing and Augmentation System	
1, 2	07/10/2017	07/14/2017	IP 7111404	Emergency Action Level and Emergency Plan Changes	
1, 2	07/10/2017	07/14/2017	IP 7111405	Correction of Emergency Preparedness Weaknesses and Deficiencies	
			<b>EP-2 - EP PERFORMANCE INDICATOR VERIFICATION</b>		<b>1</b>
1, 2	07/10/2017	07/14/2017	IP 71151-EP01	Drill/Exercise Performance	
1, 2	07/10/2017	07/14/2017	IP 71151-EP02	ERO Readiness	
1, 2	07/10/2017	07/14/2017	IP 71151-EP03	Alert & Notification System Reliability	
			<b>EXAM - INITIAL EXAM</b>		<b>5</b>
1	01/22/2018	01/26/2018	X02628	INITIAL EXAM ANO UNIT 1-(05/18)	

This report does not include INPO and OUTAGE activities.  
This report shows only on-site and announced inspection procedures.

Enclosure

Page 3 of 3

08/30/2016 09:31:17

Report 22

**Arkansas Nuclear One  
Inspection / Activity Plan  
07/01/2016 - 06/30/2018**

Unit Number	Planned Dates		Inspection Activity	Title	No. of Staff on Site
	Start	End			
			<b>EXAM - INITIAL EXAM</b>		<b>5</b>
1	02/26/2018	03/02/2018	X02628	INITIAL EXAM ANO UNIT 1-(05/18)	
			<b>CAL QTR4 - CAL CLOSURE INSPECTION QTR4</b>		<b>4</b>
1,2	10/01/2017	12/31/2017	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>EB1-07T - ANO HEAT SINK PERFORMANCE</b>		<b>1</b>
1,2	10/30/2017	11/03/2017	IP 7111107T	Heat Sink Performance	
			<b>RS 24 - RADIATION SAFETY</b>		<b>3</b>
1,2	11/06/2017	11/10/2017	IP 71124.02	Occupational ALARA Planning and Controls	
1,2	11/06/2017	11/10/2017	IP 71124.04	Occupational Dose Assessment	
			<b>CAL QTR1 - CAL CLOSURE INSPECTION QTR1</b>		<b>4</b>
1,2	01/01/2018	03/31/2018	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>EB2-03 - POST-APPROVAL LICENSE RENEWAL (TEAM)</b>		<b>4</b>
2	01/22/2018	01/26/2018	IP 71003	Post-Approval Site Inspection for License Renewal	
2	02/05/2018	02/09/2018	IP 71003	Post-Approval Site Inspection for License Renewal	
			<b>CAL QTR2 - CAL CLOSURE INSPECTION QTR2</b>		<b>4</b>
1,2	04/01/2018	06/30/2018	IP 92702	Followup On Corrective Actions For Violations And Deviations	
			<b>7111108 - INSERVICE INSPECTION 1R27</b>		<b>1</b>
1	04/09/2018	04/20/2018	IP 7111108P	Inservice Inspection Activities - PWR	

This report does not include INPO and OUTAGE activities.  
This report shows only on-site and announced inspection procedures.

Enclosure

In Staff Requirements Memorandum – SECY 16-0009, “Recommendations Resulting from the Integrated Prioritization and Re-Baselining of Agency Activities,” the Commission approved the NRC staff recommendation to discontinue the formal mid-cycle assessment process beginning in calendar year 2017. This will be the final mid-cycle assessment letter. The staff will continue to conduct quarterly assessment meetings and communicate changes in the assessment of licensee performance in accordance with the guidance in Inspection Manual Chapter 0305, “Operating Reactor Assessment Program.”

In accordance with Title 10 of the *Code of Federal Regulations* (10 CFR) 2.390 of the NRC’s “Rules of Practice,” a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC’s Agencywide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Please contact Mr. Neil O’Keefe at 817-200-1574 with any questions you have regarding this letter.

Sincerely,

*/RA/*

Kriss M. Kennedy  
Regional Administrator

Docket Nos. 50-313, 50-368  
License Nos. DPR-51, NPF-6

Enclosure:  
Arkansas Nuclear One Units 1 and 2  
Inspection/Activity Plan

DISTRIBUTION:  
See next page

**ADAMS ACCESSION NUMBER: ML16237A412**

<input checked="" type="checkbox"/> SUNSI Review By: CFO		ADAMS <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		Keyword: NRC-002
OFFICE: RIV	C: DRP/E	C: DRP/E	D: DRS	D: DRP	RIV/RA			
NAME	JDixon	NO’Keefe	AVegel	TWPruett	KKennedy			
SIGNATURE	<i>/RA/</i>	<i>/RA/</i>	<i>/RA/</i>	<i>/RA/</i>	<i>/RA/</i>			
DATE	8/18/16	8/18/16	8/18/16	8/22/16	8/24/16			

**OFFICIAL RECORD COPY**

Letter to Clay Warren from Kriss M. Kennedy dated August 31, 2016

SUBJECT: MID-CYCLE ASSESSMENT LETTER FOR ARKANSAS NUCLEAR ONE,  
UNITS 1 AND 2 (REPORT 05000313/2016005 AND 05000368/2016005)

DISTRIBUTION:

Regional Administrator (Kriss.Kennedy@nrc.gov)  
Deputy Regional Administrator (Scott.Morris@nrc.gov)  
DRP Director (Troy.Pruett@nrc.gov)  
DRS Director (Anton.Vegel@nrc.gov)  
DRS Deputy Director (Jeff.Clark@nrc.gov)  
DRP Deputy Director (Ryan.Lantz@nrc.gov)  
Senior Resident Inspector (Brian.Tindell@nrc.gov)  
Resident Inspector (Margaret.Tobin@nrc.gov)  
Resident Inspector (Andy.Barrett@nrc.gov)  
Branch Chief, DRP/E (Neil.Keefe@nrc.gov)  
Senior Project Engineer, DRP/E (John.Dixon@nrc.gov)  
Project Engineer, DRP/E (Brian.Correll@nrc.gov)  
Project Engineer, DRP/E (Jackson.Choate@nrc.gov)  
Administrative Assistant (Mary.Bennett@nrc.gov)  
Public Affairs Officer (Victor.Dricks@nrc.gov)  
Project Manager (Stephen.Koenick@nrc.gov)  
Team Leader, DRS/IPAT (Thomas.Hipschman@nrc.gov)  
ACES (R4Enforcement.Resource@nrc.gov)  
RITS Coordinator (Marisa.Herrera@nrc.gov)  
Regional Counsel (Karla.Fuller@nrc.gov)  
Technical Support Assistant (Loretta.Williams@nrc.gov)  
Congressional Affairs Officer (Jenny.Weil@nrc.gov)  
RIV Congressional Affairs Officer (Angel.Moreno@nrc.gov)  
RIV/ETA: OEDO (Jeremy.Bowen@nrc.gov)  
RIV RSLO (Bill.Maier@nrc.gov)  
Director, DIRS, NRR (Chris.Miller@nrc.gov)  
Deputy Director, DIRS, NRR (Shana.Helton@nrc.gov)  
Director, DORL, NRR (Anne.Boland@nrc.gov)  
Deputy Director, DORL, NRR (George.Wilson@nrc.gov)  
Director, NSIR (Brian.Holian@nrc.gov)  
Director, DPR, NSIR (Marissa.Bailey@nrc.gov)  
DRP Branch Chiefs (R4DRPBC@nrc.gov)  
DRS Branch Chiefs (R4DRSBC@nrc.gov)  
ROPreports.Resource@nrc.gov  
ROPassessment.Resource@nrc.gov  
RidsOeMailCenter.Resource@nrc.gov

September 12, 2016

Clay Warren, Acting Site Vice President  
Arkansas Nuclear One  
Entergy Operations, Inc.  
1448 SR 333  
Russellville, AR 72802-0967

SUBJECT: ERRATA FOR MID-CYCLE ASSESSMENT LETTER FOR ARKANSAS  
NUCLEAR ONE, UNITS 1 AND 2 (REPORT 05000313/2016005 AND  
05000368/2016005)

Dear Mr. Warren:

It was identified that the enclosed inspection plan in a letter to you dated August 31, 2016 (ML16237A412) was improperly marked. The inspection plan contained the markings of "Official Use Only – Sensitive Internal Information/Security-Related Information", however, the inspection plan did not contain information under that category. The inspection plan that was originally placed into ADAMS has been corrected by striking through the markings. The original Mid-Cycle Assessment Letter and the corrected inspection plan are enclosed. Please note that neither the content of the assessment letter, nor the inspection plan has changed.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, its enclosure, and your response (if any) will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's Agency wide Document Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

*/RA/*

Thomas R. Hipschman, Team Leader  
Inspection Program and Assessment Team  
Division of Reactor Safety

Docket Nos.: 50-313, 50-368  
License Nos.: DPR-51, NPF-6

Enclosures:

1. Arkansas Nuclear One Units 1 and 2  
Inspection/Activity Plan
2. 2016 Mid-Cycle Assessment  
Letter (ML16237A412)

**DISTRIBUTION:**

See next page

**ADAMS ACCESSION NUMBER: ML16256A298 / PACKAGE: ML16256A293**

<input checked="" type="checkbox"/> SUNSI Review		ADAMS		<input checked="" type="checkbox"/> Publicly Available		<input checked="" type="checkbox"/> Non-Sensitive		Keyword: NRC-002
By: EDU		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Non-Publicly Available		<input type="checkbox"/> Sensitive		
OFFICE	TL:IPAT							
NAME	THipschman							
SIGNATURE	<i>/RA/</i>							
DATE	9/12/16							

OFFICIAL RECORD COPY

Letter to Clay Warren from Thomas R. Hipschman dated September 12, 2016

SUBJECT: ERRATA FOR MID-CYCLE ASSESSMENT LETTER FOR ARKANSAS  
NUCLEAR ONE, UNITS 1 AND 2 (REPORT 05000313/2016005 AND  
05000368/2016005)

DISTRIBUTION:

Regional Administrator (Kriss.Kennedy@nrc.gov)  
Deputy Regional Administrator (Scott.Morris@nrc.gov)  
DRP Director (Troy.Pruett@nrc.gov)  
DRS Director (Anton.Vegel@nrc.gov)  
DRS Deputy Director (Jeff.Clark@nrc.gov)  
DRP Deputy Director (Ryan.Lantz@nrc.gov)  
Senior Resident Inspector (Brian.Tindell@nrc.gov)  
Resident Inspector (Margaret.Tobin@nrc.gov)  
Resident Inspector (Andy.Barrett@nrc.gov)  
Branch Chief, DRP/E (Neil.Keefe@nrc.gov)  
Senior Project Engineer, DRP/E (John.Dixon@nrc.gov)  
Project Engineer, DRP/E (Brian.Correll@nrc.gov)  
Project Engineer, DRP/E (Jackson.Choate@nrc.gov)  
Administrative Assistant (Mary.Bennett@nrc.gov)  
Public Affairs Officer (Victor.Dricks@nrc.gov)  
Project Manager (Stephen.Koenick@nrc.gov)  
Team Leader, DRS/IPAT (Thomas.Hipschman@nrc.gov)  
ACES (R4Enforcement.Resource@nrc.gov)  
RITS Coordinator (Marisa.Herrera@nrc.gov)  
Regional Counsel (Karla.Fuller@nrc.gov)  
Technical Support Assistant (Loretta.Williams@nrc.gov)  
Congressional Affairs Officer (Jenny.Weil@nrc.gov)  
RIV Congressional Affairs Officer (Angel.Moreno@nrc.gov)  
RIV/ETA: OEDO (Jeremy.Bowen@nrc.gov)  
RIV RSLO (Bill.Maier@nrc.gov)  
Director, DIRS, NRR (Chris.Miller@nrc.gov)  
Deputy Director, DIRS, NRR (Shana.Helton@nrc.gov)  
Director, DORL, NRR (Anne.Boland@nrc.gov)  
Deputy Director, DORL, NRR (George.Wilson@nrc.gov)  
Director, NSIR (Brian.Holian@nrc.gov)  
Director, DPR, NSIR (Marissa.Bailey@nrc.gov)  
DRP Branch Chiefs (R4DRPBC@nrc.gov)  
DRS Branch Chiefs (R4DRSBC@nrc.gov)  
ROPreports.Resource@nrc.gov  
ROPassessment.Resource@nrc.gov