

**Summary of Inspection Results for TI 2515/184, "Availability and Readiness Inspection of Severe Accident Management Guidelines (SAMGs)"**

Plant / Site	Region	03.01(a)				03.01(b)	03.01(c)	03.01(d)	03.01(f) (see footnote 2)			03.01(g)
		Does the licensee have SAMG procedures? (see footnote 1)	Are controlled copies of the SAMG located in the technical support center (TSC)? (Y/N)	Are controlled copies of the SAMG located in the emergency operations facility (EOF)? (Y/N)	Are controlled copies of the SAMG located in the control room? (Y/N)	Are SAMGs covered by the licensee's procedure control and document management system, including the requirements for periodic review and revision? (Y/N)	Does the licensee's configuration control and change management systems (e.g., 10CFR50.59 process) cause the licensee to update SAMGs to reflect design changes? (Y/N/Partially)	Are the SAMGs consistent with the owners group guidance (if any) having been incorporated? (Y/N)	Did personnel receive initial training on the SAMGs? (Y/N)	Did personnel receive periodic training on the SAMGs and how they relate to their assigned duties? (Y/N)	Can personnel articulate their responsibilities with respect to the use of SAMGs? (Y/N)	Have there been periodic exercises on the use of SAMGs by individuals who would implement them during an emergency? (Y/N)
Beaver Valley	I	Y	Y	N	Y	Y	Y	Y	Y	N	N	N
Calvert Cliffs	I	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	Y
Fitzpatrick	I	Y	Y	Y	Y	N	Y	Y	N	N	N	N
Ginna	I	Y	Y	N	Y	Y	N	Y	Y	Y	Y	N
Hope Creek	I	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y
Indian Point 2	I	Y	Y	N	Y	N	Y	Y	Y	Y	Y	Y
Indian Point 3	I	Y	Y	N	Y	N	Y	Y	Y	Y	Y	Y
Limerick	I	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
Millstone	I	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	N
Nine Mile Point	I	Y	Y	Y	Y	N	Y	Y	N	N	Y	Y
Oyster Creek	I	Y	Y	N	Y	N	Y	Y	Y	Y	Y	Y
Peach Bottom	I	Y	Y	Y	Y	N	Y	Y	Y	Y	N	Y
Pilgrim	I	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	N
Salem	I	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y
Seabrook	I	Y	Y	Y	Y	Y	N	Y	Y	Y	Y	N
Susquehanna	I	Y	Y	Y	N	Y	Y	Y	Y	N	Y	N
Three Mile Island	I	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
Vermont Yankee	I	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
Browns Ferry	II	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
Brunswick	II	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Catawba	II	Y	Y	Y	Y	N	N	Y	Y	Y	Y	Y
Crystal River	II	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	N
Farley	II	Y	Y	N	Y	N	Y	Y	Y	Y	Y	Y
Harris	II	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	N
Hatch	II	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	N
McGuire	II	Y	Y	Y	Y	N	N	Y	Y	Y	Y	Y
North Anna	II	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	N
Oconee	II	Y	Y	N	N	N	N	Y	Y	Y	Y	Y
Robinson	II	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
Sequoyah	II	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
St. Lucie	II	Y	Y	Y	N	Y	Y	Y	Y	Y	Y	Y
Summer	II	Y	Y	Y	Y	Y	N	N	Y	Y	Y	N
Surry	II	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
Turkey Point	II	Y	Y	Y	Y	N	N	Y	Y	Y	Y	N
Vogtle	II	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y
Watts Bar	II	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Braidwood	III	Y	Y	N	Y	N	Y	N	Y	Y	Y	Y
Byron	III	Y	Y	N	Y	N	Y	N	Y	Y	Y	N
Clinton	III	Y	Y	N	Y	N	Y	Y	Y	Y	Y	Y
D.C. Cook	III	Y	Y	Y	Y	N	N	Y	Y	Y	Y	N
Davis-Besse	III	Y	Y	N	Y	Y	N	Y	Y	Y	Y	N
Dresden	III	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	N
Duane Arnold	III	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Fermi	III	Y	Y	N	Y	N	Y	Y	Y	N	N	N

**Summary of Inspection Results for TI 2515/184, "Availability and Readiness Inspection of Severe Accident Management Guidelines (SAMGs)"**

Plant / Site	Region	03.01(a)				03.01(b)	03.01(c)	03.01(d)	03.01(f) (see footnote 2)			03.01(g)
		Does the licensee have SAMG procedures? (see footnote 1)	Are controlled copies of the SAMG located in the technical support center (TSC)? (Y/N)	Are controlled copies of the SAMG located in the emergency operations facility (EOF)? (Y/N)	Are controlled copies of the SAMG located in the control room? (Y/N)	Are SAMGs covered by the licensee's procedure control and document management system, including the requirements for periodic review and revision? (Y/N)	Does the licensee's configuration control and change management systems (e.g., 10CFR50.59 process) cause the licensee to update SAMGs to reflect design changes? (Y/N/Partially)	Are the SAMGs consistent with the owners group guidance (if any) having been incorporated? (Y/N)	Did personnel receive initial training on the SAMGs? (Y/N)	Did personnel receive periodic training on the SAMGs and how they relate to their assigned duties? (Y/N)	Can personnel articulate their responsibilities with respect to the use of SAMGs? (Y/N)	Have there been periodic exercises on the use of SAMGs by individuals who would implement them during an emergency? (Y/N)
Kewaunee	III	Y	Y	Y	Y	N	Y	N	Y	N	Y	N
LaSalle	III	Y	Y	Y	Y	Y	Y	Y	N	N	Y	Y
Monticello	III	Y	Y	Y	Y	N	Y	Y	Y	N	N	N
Palisades	III	Y	Y	Y	N	N	N	Y	N	N	N	N
Perry	III	Y	Y	Y	Y	Y	N	Y	Y	Y	Y	N
Point Beach	III	Y	Y	Y	Y	Y	Y	N	Y	Y	Y	Y
Prairie Island	III	Y	Y	Y	Y	N	Y	N	N	N	Y	Y
Quad Cities	III	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y
Arkansas Nuclear	IV	Y	Y	Y	Y	N	Partially	Y	Y	Y	Y	Y
Callaway	IV	Y	Y	Y	N	N	N	Y	Y	Y	Y	N
Columbia	IV	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y
Comanche Peak	IV	Y	N	N	N	N	N	N	Y	Y	Y	N
Cooper	IV	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	Y
Diablo Canyon	IV	Y	Y	Y	Y	Y	Partially	Y	Y	Y	Y	Y
Fort Calhoun	IV	Y	Y	Y	Y	N	N	Y	Y	Y	Y	Y
Grand Gulf	IV	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	Y
Palo Verde	IV	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	N
River Bend	IV	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
San Onofre	IV	Y	Y	Y	Y	Y	N	Y	Y	N	Y	Y
South Texas	IV	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	N
Waterford	IV	Y	N	N	N	N	Partially	Y	Y	Y	Y	Y
Wolf Creek	IV	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y

(1) See the individual plant data sheets regarding information on "when the SAMGs were last updated" as referred to in TI 2515/184 Section 03.01(a).

(2) Specific answers to training questions associated with Inspection Item 03.01(e) are not included in the matrix, however, an overview of the training program is included in the matrix under Item 03.01(f). The