



Steam Generator Tube Degradation

Bill Borchardt
Executive Director For Operations
February 7, 2013

Agenda

- **Opening Remarks**
 - **Bill Borchardt, Eric Leeds**
- **Accident Analysis**
 - **Chris Jackson**
- **Operating Experience/Oversight**
 - **Ken Karwoski**

Accident Analysis

Chris Jackson
Branch Chief
Reactor Systems Branch, NRR

Safety Analyses

- **Final Safety Analysis Report**
- **Anticipated Operational Occurrences and Accidents**
- **Objectives for Design Basis Accidents**
 - **Fuel Design Limits**
 - **RCS Pressure Boundary**
 - **Containment Design**
 - **Dose Consequences**

Safety Analyses

- **Steam generator tubes transfer heat from the reactor to the turbine**
- **Steam generators form a barrier between the reactor coolant and steam system**

Safety Analyses

- **Steam generators provide an input to many important accident analyses**
 - **RCS flow, heat removal, steam pressure, core inlet and exit temperature, power**
- **Failure of steam generator tube is an accident (SGTR)**

Steam Generator Tube Rupture is a Design Basis Accident

- **SRP Section 15.6.3**
 - **Dose Perspective**
- **Not limiting**
 - **Fuel Design**
 - **Containment**

Steam Generator Tube Rupture is a Design Basis Accident

- **Reactor Operators Play an Important Role in plant Recovery**
- **Operators are Trained and Tested on this event**

Ginna Event

- **In 1982 a tube rupture occurred at Ginna**
 - **Steam side of steam generators filled with water**
 - **Water entered the steam lines**
 - **Water was discharged through steam relief valves into atmosphere**

GINNA Event

- **NRC issued GLs 1982-07, 08, 11**
- **Licensees took action through Owners Group initiative to improve SGTR recovery capability**
 - **WCAP-10698-P-A (ML071430455)**

Safety Analyses - Conclusion

- **SGTR is not a limiting event from a fuel damage or containment pressure perspective**
- **SGTR accident analysis demonstrates that dose consequence are within the regulatory limit**


**Steam Generator
Operating Experience
and Oversight**

**Ken Karwoski
Senior Level Advisor
Division of Engineering, NRR**


Steam Generator Designs

- **2 major types of steam generators**
 - **Recirculating: “U-shaped” tubes**
 - **Once-through: Straight tubes**
- **Steam generator tube materials**
 - **Mill Annealed Alloy 600 (600MA)**
 - **Thermally treated Alloy 600 (600TT)**
 - **Thermally treated Alloy 690 (690TT)**


Recirculating and Once Through Steam Generators



Recirculating




Recirculating



Once Through

Types of Tube Degradation




Managing Tube Degradation

- **Degradation has led to industry proposals to implement various tube repair criteria and methods**
- **Operating conditions and maintenance can affect steam generator lifetime**
- **Staff's focus is on tube integrity**

Steam Generator Replacements

- **57 of 69 units have replaced**
- **Incorporated design enhancements to address degradation**
- **Replaced using 10 CFR 50.59 process since 1989**
 - **Regional Inspections**

Units in Operation: 1968-2012



■ 304SS ■ 600MA ■ 600TT ■ 690TT

Cracking in Alloy 600TT Tubing

- **First instance of cracking detected in 2002 (2nd generation tube material)**
- **Since 2002, cracks detected at several locations along tube length**
- **Number and severity of cracks, to date, has been minor**


Steam Generator Tube Wear

- **Detected in both original and replacement steam generators**
- **Number of indications of detected wear varies from none to thousands**
- **Severity of wear determines the safety significance not the number of indications**

Tube-to-Tube Wear - Replacement Once Through Steam Generators

- **Indications attributed to tube-to-tube contact in Fall 2011**
- **Wear is shallow and slow growing**
- **Root cause evaluation underway**

Tube-to-Tube Wear – Once Through Steam Generators



San Onofre Tube Wear

- **Mitsubishi replacement recirculating steam generators**
- **Unit 2 wear**
 - **Loose parts/foreign objects**
 - **Tube supports and retainer bar**
 - **Tube-to-tube wear**
- **Unit 2 operated full cycle and maintained tube integrity**

San Onofre Tube Wear (cont.)

- **Unit 3 shut down half way through cycle due to primary-to-secondary leakage**
- **Unit 3 wear**
 - **Tube supports and Retainer bar**
 - **Tube-to-tube wear**
- **8 tubes did not have adequate tube integrity in Unit 3**

Regulatory Framework

- **Inspection/Repair of tubes governed by plant technical specifications**
- **Original technical specifications developed in 1970s**
- **Improved specifications are risk informed, performance based**
- **All plants have adopted**

NRC Oversight/Monitoring

- **Multi-Tiered approach**
 - **Regional activities**
 - **Headquarters activities**
 - **Industry interactions**
- **Public Transparency**

NRC Research Activities

- **Steam generator research performed since 1970s**
 - **Inspection**
 - **Integrity**
 - **Corrosion**
- **International Steam Generator Tube Integrity Program**


Industry Program

- **Industry responded to emerging degradation**
- **Industry standardized programs for addressing steam generator issues**
 - **Water Chemistry Guidelines**
 - **Inspection and Integrity Guidelines**
 - **Primary-to-Secondary Leakage Guidelines**


Steam Generator Performance

- **Performance has improved since 1970s**
- **Prior to 2012 last time a plant did not have adequate tube integrity was 2003**

Forced Outage Frequency: Primary-to-Secondary Leakage



Steam Generator Tube Rupture Frequency



Defense-in-Depth

- **Design**
- **Design Basis Accident**
- **Operator Training**
- **Tube Inspections and Assessments**
- **Operational Programs**
- **Risk Significance**

Summary

- **Steam generator tubes may degrade**
- **Degradation can be managed**
- **Staff monitors steam generator operating experience**
- **Staff's focus is on tube integrity**
- **Performance has improved**

Acronyms

- **avg. - average**
- **CFR – Code of Federal Regulations**
- **cont. - continued**
- **GL – generic letter**
- **IGA - intergranular attack**
- **MA - mill annealed**
- **NRC - Nuclear Regulatory Commission**
- **NRR – Office of Nuclear Reactor Regulation**
- **ODSCC - outside diameter stress corrosion cracking**
- **PWR - pressurized water reactor**

Acronyms (cont.)

- **PWSCC** – primary water stress corrosion cracking
- **RCS** – reactor coolant system
- **SG** – steam generator
- **SGTR** – steam generator tube rupture
- **SRP** – standard review plan
- **SS** – stainless steel
- **TT** – thermally treated
- **yr** - year