



**DTE Energy®**

**Fermi 3  
Combined License Mandatory Hearing  
Safety - Panel 2**



# DTE Has Addressed Post-Fukushima Recommendations for Fermi 3



- ESBWR passive design substantially resolves Fukushima Near-Term Task Force (NTTF) Recommendations
- Aspects of NTTF Recommendations supplemented in COLA and that will be addressed in COL:
  - 2.1 Seismic Evaluation (previously discussed)
  - 4.2 Mitigating Strategies for Beyond-Design-Basis External Events
    - Draft License Condition to implement FLEX
  - 7.1 Reliable Spent Fuel Pool Instrumentation
    - Draft License Condition for operator training
  - 9.3 Emergency Preparedness
    - Draft License Condition for staffing and communication assessments