



FERC

Federal Energy Regulatory Commission

Geomagnetic Disturbances (GMD) Rulemaking

Kal Ayoub, Deputy Division Director
Office of Electric Reliability
Division of Reliability Standards and Security

October 21, 2015



FERC

Federal Energy Regulatory Commission

FERC Order No. 779

- Issued May 2013
- The Commission directed NERC to develop and submit for approval proposed Reliability Standards that address the impact of geomagnetic disturbances on the reliable operation of the Bulk-Power System.
- The Commission directed NERC to implement the directive in two stages.



FERC

Federal Energy Regulatory Commission

NERC EOP-010-1

- In response to the stage 1 directive from Order No. 779, NERC drafted EOP-010-1 - Geomagnetic Disturbance Operations.
 - Requires entities to “develop, maintain, and implement a GMD Operating Plan to coordinate GMD Operating Procedures”.
- FERC Order 797
 - Issued June 2014.
 - Approved NERC Reliability Standard EOP-010-1, effective April 1, 2015.



FERC

Federal Energy Regulatory Commission

NERC TPL-007-1

- In response to the stage 2 directive from Order No. 779, NERC drafted TPL-007-1 - Geomagnetic Disturbance Mitigation.
 - Requires entities to perform GMD Vulnerability Assessments using studies based upon AC system models and geomagnetically-induced current (GIC) system models.
 - Entities with systems which do not meet the performance requirements of the standard must develop Corrective Action Plans.
 - Entities with transformers identified as vulnerable by the standard are required to conduct thermal assessments of those transformers.
 - All studies and assessments must be based on the NERC Benchmark GMD Event defined in the standard.



FERC

Federal Energy Regulatory Commission

NERC Proposed Benchmark GMD Event

- The Benchmark GMD Event defines a reference geoelectric field which is scaled to the peak electric field, $E_{PEAK} = \alpha \times \beta \times 8$ (V/km).
 - α is the local geomagnetic latitude scaling factor.
 - β is the local earth conductivity scaling factor.
 - The 8 V/km portion is based on a statistical study of IMAGE magnetometer data from 1993 to 2013 with spatial averaging over 500km squares to estimate a 1 in 100 year geoelectric field amplitude.



FERC

Federal Energy Regulatory Commission

FERC Notice of Proposed Rulemaking (NOPR) (RM15-11-000)

- NOPR issued on May 14, 2015, proposing to approve TPL-007-1. NOPR proposed modifications:
 - modify the “benchmark GMD event” so that the “reference peak geoelectric field amplitude” component of the definition is not based solely on spatially-averaged data.
 - develop revisions to the proposed Reliability Standard to require installation of monitoring equipment.
 - develop revisions to the proposed Reliability Standard to establish specific deadlines for the development of corrective action plans and the completion of activities called for in corrective action plans.
 - study and submit informational filings addressing areas including spatial averaging, earth conductivity models, and how data from geomagnetically-induced current monitors and magnetometers can be made available to researchers.