



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

# **ACRS MEETING WITH THE U.S. NUCLEAR REGULATORY COMMISSION**

**March 4, 2016**



# **Overview**

**Dennis C. Bley**

# **Accomplishments**

**Since our last meeting with the Commission on June 11, 2015, we issued 17 Reports**

- **10 CFR 50.46c Rulemaking Activities**
- **Maximum Extended Load Line Limit Analysis Plus (MELLLA+) License Amendment Requests**
  - **Grand Gulf, NMP 2, Peach Bottom 2/3**
- **Fukushima: Plans for Resolving the NRC Near-Term Task Force Open Tier 2 and 3 Recommendations**

# Reports

- **COLA: Duke Energy Carolinas, LLC, William States Lee III Nuclear Station, Units 1 and 2**
- **Construction Permit: SHINE Medical Technologies, Inc. Medical Isotope Production Facility**
- **Early Site Permit: PSEG site adjacent to Salem and Hope Creek on Artificial Island in New Jersey**

# Reports

- **License Renewal Applications**
  - **Byron Station Units 1 and 2 and Braidwood Station Units 1 and 2**
  - **Davis-Besse Nuclear Power Station**
- **RMRF: Draft SECY Paper, Recommendations on Issues Related to Implementation of a Risk Management Regulatory Framework**

# Reports

- **Fukushima: Draft Regulatory Basis for Containment Protection and Release Reduction for Mark I and Mark II Boiling Water Reactors**
- **Guidance and Bases**
  - **Interim Staff Guidance: DC/COL-ISG-028, “Assessing the Technical Adequacy of the Advanced Light-Water Reactor Probabilistic Risk Assessment for the Design Certification Application and Combined License Application”**

# Reports

- **Interim Staff Guidance, “Guidance for the Evaluation of Acute Chemical Exposures and Proposed Quantitative Standards”**
- **Reactor Oversight Process Enhancements**
- **Revised Fuel Cycle Oversight Process Cornerstones**
- **ACRS Assessment of the Quality of Selected NRC Research Projects – FY2015**

# Ongoing / Future Reviews

- **Fukushima**

- **NRC Near-Term Task Force Fukushima Tier 2 and 3 Recommendations – Groups 2 & 3**
- **Update to JLD-ISG-2012-05, “Guidance for Performing the Integrated Assessment for External Flooding”**
- **Mitigation of Beyond-Design-Basis Events Rulemaking Update**

# Ongoing / Future Reviews

- **New Plants**
  - **Subsequent COLAs for AP1000 (Levy & Turkey Point) and ESBWR (North Anna)**
  - **APR 1400**
- **Research and Test Reactor License Renewal Process Rulemaking**
- **Biennial Review and Evaluation of the NRC Safety Research Program**

# Ongoing / Future Reviews

- **License Renewal**
  - **Fermi**
  - **Grand Gulf**
  - **LaSalle**
  - **Seabrook**
  - **South Texas Project**
- **Subsequent License Renewal**
- **Radiation Protection**
  - **10 CFR Part 61 Rulemaking**

# Ongoing / Future Reviews

- **Digital I&C**

- **SECY Paper on Cyber Security Control of Access**
- **SECY Paper on Cyber Security for Fuel Cycle Facilities**
- **SECY Paper on Digital I&C Diversity and Defense-in-Depth**
- **Diablo Canyon Digital Replacement**

# Ongoing / Future Reviews

- **Reliability and PRA**
  - **Level 3 PRA**
  - **Human Reliability Analysis Methods**
  - **Risk-Informed Resolution of GSI-191, “Assessment of Debris Accumulation on PWR Sump Performance”**
  - **NuScale Topical Report, “Risk Significance Determination – Use of RAW Importance Measure”**

# **Ongoing / Future Reviews**

- **Metallurgy and Reactor Fuels**
  - **Spent Fuel Storage and Transportation**
  - **Dry Fuel Storage Generic Aging**
  - **Draft Regulatory Basis for 10 CFR Part 50, Appendix H, “Reactor Vessel Material Surveillance Program Requirements”**

# Ongoing / Future Reviews

- **Thermal-Hydraulic Phenomenology**
  - **Westinghouse Realistic Full Spectrum LOCA Methodology**
  - **Supplement to Topical Report on BISON code**



**Draft Final Rule for  
10 CFR 50.46c, “Emergency  
Core Cooling System  
Performance During  
Loss-of-Coolant Accidents”**

**Ronald Ballinger**



# **10 CFR 50.46c Rulemaking Goals**

- **Revise ECCS acceptance criteria to reflect extensive research findings**
  - **High burnup effects on cladding ductility**
- **Replace prescriptive criteria with performance-based requirements\***
- **Applicability to all fuel designs/cladding materials**
- **Allow an alternative risk-informed approach to evaluate the effects of debris on long-term cooling\***

**\* Response to Commission Directive**

# LOCA Research and Testing Program Results

- **Significant reduction in cladding ductility at high burnup**
  - Hydrogen absorption effect on ductility
- **Breakaway oxidation during LOCA transient**
  - Transition from adherent to non-adherent oxide-accelerated hydrogen absorption



# **New 10 CFR 50.46c Rule**

- **Maintains peak clad temperature and hydrogen limits**
  - **Peak clad temperature: 2200°F**
  - **Maximum cladding reacted: 1%**
- **Adjusts equivalent cladding oxidized to reflect burnup effect**
- **Requires analytical limits for peak cladding temperature and integral time-at-temperature to be developed that account for the effects of exposure.**
- **Requires accounting for breakaway oxidation**
- **Allows use of risk-informed methods for long-term cooling**

# **10 CFR 50.46c Related** **Regulatory Guides**

- **Staff developed RGs 1.222, 1.223, and 1.224 to provide methods acceptable to meet the requirements for fuel performance.**
  - RG 1.222 “Measuring Breakaway Oxidation Behavior”
  - RG 1.223, “Determining Post Quench Ductility”
  - RG 1.224, “Establishing Analytical Limits for Zirconium-Alloy Cladding Material”
- **Staff developed RG 1.229 to provide methods to meet requirements for long-term cooling**
  - RG 1.229 “Risk-informed Approach for Addressing the Effects of Debris on Post-accident Long-term Core Cooling”

# **10 CFR 50.46c Implementation**

## **Existing Fleet**

- **Implementation plan six months after the effective date of the rule**
- **All license amendment requests for compliance must be submitted no later than 60 months after the effective date of the rule and must be completed no later than 84 months**

# **ACRS Recommendations**


- **The draft final rule 10 CFR 50.46c and associated RGs 1.222, 1.223 and 1.224 should be issued**
- **RG 1.229 still in draft form should not be issued-further review in process**
  - **March 2016 Subcommittee**
  - **April 2016 Full Committee**



# **Maximum Extended Load Line Limit Analysis Plus (MELLLA+)**

**Joy L. Rempe**

# Simplified Power to Flow Map



MELLLA = Maximum Extended Load Line Limit  
MELLLA+ = Maximum Extended Load Line Limit Plus  
EPU = Extended Power Uprate  
ICU = Increased Core Flow

Graphic: NUREG/CR-7179

- **BWRs control power using two options: control rod movements and flow adjustments**
- **Expanded MELLLA+ flow window increases operational flexibility and safety**
- **Additional measures needed for maintaining margins to power and flow instabilities in MELLLA+**

# **ACRS MELLLA+ Reviews**

- **GE-Hitachi MELLLA+ licensing topical reports identify scope and provide generic analyses needed to meet safety and regulatory requirements**
  - **ACRS review focused on analytical uncertainties and limitations needed to preserve safety margin**
- **Four MELLLA+ license amendment requests**
  - **ACRS review emphasized uncertainties in plant-specific evaluations to assess safety margin**

# MELLLA+ Implementation

Parameter	Monticello	Peach Bottom Units 2 and 3	Nine Mile Point Unit 2	Grand Gulf Units 1 and 2
Type	BWR3	BWR4	BWR5	BWR6
Containment	Mark I	Mark I	Mark II	Mark III
Power (MWt)	2004	3951	3988	4408
M+ region lowest rated core flow	80%	83%	85%	80%
Fuel	GE14	GNF2	GE14	GNF2
Power Density (kW/liter)	~48	~58	~59	~62
Peak Power to Flow Ratio (MWt/Mlbm/hr)	~50	~55	~52	~57
Representative Compensating Measures	<ul style="list-style-type: none"> <li>-Detect and Suppress Solution- Confirmation Density (DSS-CD)</li> <li>-No Feedwater Heater Out-of-Service (FWHOOS)</li> <li>-No Single Loop Operation (SLO)</li> <li>-Time Critical Actions</li> </ul>	<ul style="list-style-type: none"> <li>-DSS-CD</li> <li>- No FWHOOS</li> <li>- No SLO</li> <li>-Time Critical Actions</li> <li>-Limits on Safety-Relief Valves (SRVs) out-of-service (OOS)</li> <li>-Increased Standby Liquid Control System (SLCS) Boron-10 (B-10) enrichment</li> </ul>	<ul style="list-style-type: none"> <li>-DSS-CD</li> <li>- No FWHOOS</li> <li>- No SLO</li> <li>-Time Critical Actions</li> <li>-Limits on SRVs OOS</li> <li>-Automated actions to initiate feedwater flow reduction</li> <li>-Increased SLCS B-10 enrichment</li> </ul>	<ul style="list-style-type: none"> <li>-DSS-CD</li> <li>-No FWHOOS</li> <li>-No SLO</li> <li>-Time Critical Actions</li> <li>-Limits on SRVs OOS</li> </ul>

# **Plant Response Evaluations**

- **Plant response evaluations consider normal operation and off-normal events**
- **Approval of GE-Hitachi MELLLA+ method contingent on limitations related to ATWS Instability:**
  - **Uncertainties in analytical models**
  - **Differences in plant design, operation, and selected compensating measures**
  - **Quantification of key “nominal” model input and associated uncertainties**

# **Anticipated Future Activities**

- **Additional expanded flow operating domain submittals expected**
  - **Additional MELLA+ license amendment requests**
  - **Other vendor licensing topical reports on extended flow operating domains**
- **Staff testing to reduce uncertainties in predicting instability phenomena**



# **Plans for Resolving Fukushima Near-Term Task Force Tier 2 and 3 Recommendations**

**John W. Stetkar**

# Background

## **SECY-11-0137 priorities:**

- **Tier 2 - need further technical assessment and alignment, depend on Tier 1 issues, or need critical skill sets**
- **Tier 3 - require further study for regulatory action, need completion of associated shorter-term action, depend on resolution of Recommendation 1, or need critical skill sets**

## **Background (cont.)**

- **Some initial Tier 2 and 3 recommendations subsumed into Tier 1 activities (e.g., Mitigation of Beyond-Design-Basis Events rulemaking and related order)**
- **Need for expedited transfer of spent fuel to dry cask storage completed in May 2014**

# **SECY-15-0137 Group 1**

- **Should be closed now**
- **Existing regulatory framework and requirements are adequate**
- **No further regulatory action is warranted**
  - **NTTF 3: Seismically-induced fires and floods**
  - **Staff: Emergency planning zone size and pre-staging of potassium iodide**
  - **NTTF 9.3: Maintain ERDS capability pending rulemaking**
  - **NTTF 10.3: ERDS enhancements**
  - **NTTF 11.2: Recovery and reentry insights**
  - **NTTF 11.4: Local community training**
  - **NTTF 12.1: Reactor Oversight Process consideration of defense-in-depth**
  - **NTTF 12.2: NRC staff and inspector training on severe accidents and SAMGs**

# **SECY-15-0137 Group 2**

- **Should be closed**
- **No further regulatory action is warranted**
- **Interaction with ACRS or external stakeholders before final assessment**
- **Closure recommendations March 2016**
  - **NTTF 5.2: Reliable hardened vents for containments other than BWR Mark I and Mark II**
  - **NTTF 6: Hydrogen control and mitigation**
  - **ACRS: Enhanced instrumentation for beyond-design-basis conditions**

# **SECY-15-0137 Group 3**

- **Assessment or documentation of basis for closure not yet completed**
- **Interaction with ACRS or external stakeholders before final assessment**
- **Closure recommendations December 2016**
  - **ACRS, Congress: Re-evaluations of natural external hazards other than seismic and flooding**
  - **NTTF 2.2: Periodic reconfirmation of external hazards**
  - **NTTF 11.3: Real-time radiation monitoring onsite and emergency planning zone**

# **ACRS Conclusions**

- **November 16, 2015 letter report**
- **Assignments of open Tier 2 and 3 recommendations into the three resolution groups are appropriate**

## **ACRS Conclusions (cont.)**

- **Existing regulatory framework and requirements are adequate, and no further regulatory action is warranted for the Group 1 recommendations**
- **ACRS will review staff evaluations and closure plans for the Group 2 and Group 3 recommendations**

# **Comments on Specific Issues**

## **Seismically-induced fires and floods**

- **Agree no new regulatory requirements are needed**
- **Staff's conclusions about risk significance may overlook scenarios from compound effects**
- **Further investigate feasibility of PRA methods to evaluate these scenarios**

# **Comments on Specific Issues** **(cont.)**

## **Mitigation of hydrogen releases**

- **Examine other pathways for release into BWR Mark I and Mark II reactor buildings**
- **Sufficient release to pose a combustion hazard with containment pressure below level mandating vent activation**
- **Findings derived from staff reviews of international activities**

# **Comments on Specific Issues** **(cont.)**

## **Enhanced instrumentation**

- **Research on capability of instruments to withstand severe accident environments**
- **Use of available (reliable) instruments and supplemental calculation aids to support SAMG actions**
- **Identify instrumentation needed before, during, and after a severe accident**

# Abbreviations

<b>ACRS</b>	<b>Advisory Committee on Reactor Safeguards</b>	<b>MELLLA</b>	<b>Maximum Extended Load Line Limit Analysis</b>
<b>ATWS</b>	<b>Anticipated Transient Without Scram</b>	<b>MELLLA+</b>	<b>Maximum Extended Load Line Limit Analysis Plus</b>
<b>BWR</b>	<b>Boiling Water Reactor</b>	<b>NMP2</b>	<b>Nine Mile Point Nuclear Station Unit 2</b>
<b>CFR</b>	<b>Code of Federal Regulations</b>	<b>NRC</b>	<b>Nuclear Regulatory Commission</b>
<b>COLA</b>	<b>Combined Operating License Application</b>	<b>NTTF</b>	<b>Near-Term Task Force</b>
<b>ISG</b>	<b>Interim Staff Guidance</b>	<b>PRA</b>	<b>Probabilistic Risk Assessment</b>
<b>DSS-CD</b>	<b>Detect and Suppress Solution – Confirmation Density</b>	<b>PSEG</b>	<b>Public Service Electric &amp; Gas Company</b>
<b>ECCS</b>	<b>Emergency Core Cooling System</b>	<b>PWR</b>	<b>Pressurized Water Reactor</b>
<b>EPU</b>	<b>Extended Power Uprate</b>	<b>RAW</b>	<b>Risk Assessment Worth</b>
<b>ESBWR</b>	<b>Economic Simplified Boiling Water Reactor</b>	<b>RG</b>	<b>Regulatory Guide</b>
<b>FWHOOS</b>	<b>Feedwater Heater Out-of-Service</b>	<b>RMRF</b>	<b>Risk Management Regulatory Framework</b>
<b>GE</b>	<b>General Electric</b>	<b>SAMG</b>	<b>Severe Accident Management Guidelines</b>
<b>GNF</b>	<b>Global Nuclear Fuel Americas, LLC</b>	<b>SECY</b>	<b>Office of the Secretary</b>
<b>GSI</b>	<b>Generic Safety Issue</b>	<b>SHINE</b>	<b>SHINE Medical Technologies, Inc.</b>
<b>I&amp;C</b>	<b>Instrumentation &amp; Control</b>	<b>SLCS</b>	<b>Standby Liquid Control System</b>
<b>ICU</b>	<b>Increase Core Flow</b>	<b>SLO</b>	<b>Single Loop Operation</b>
<b>LOCA</b>	<b>Loss of Coolant Accident</b>	<b>SRV</b>	<b>Safety-Relief Valve</b>